

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**

**Bid Receiving
PWGSC
33 City Centre Drive
Suite 480
Mississauga
Ontario
L5B 2N5
Bid Fax: (905) 615-2095**

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
Ontario Region
33 City Centre Drive
Suite 480
Mississauga
Ontario
L5B 2N5

Title - Sujet BLDG. MAINTENANCE SERVICES	
Solicitation No. - N° de l'invitation KW405-110691/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client KW405-11-0691	Date 2012-09-21
GETS Reference No. - N° de référence de SEAG PW-\$TOR-212-5990	
File No. - N° de dossier TOR-1-34243 (212)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-10-10	
Time Zone Fuseau horaire Eastern Daylight Saving Time EDT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Shaw, Marian	Buyer Id - Id de l'acheteur tor212
Telephone No. - N° de téléphone (905) 615-2065 ()	FAX No. - N° de FAX (905) 615-2060
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DEPARTMENT OF THE ENVIRONMENT ADMINISTRATION NWRI 867 LAKESHORE ROAD, P.O BOX 5050 BURLINGTON, ONTARIO L7R 4A6	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment Number 001 is being issued to make the following changes and provide questions and answers from the Mandatory Site Visit as well as provide answers to bidders questions received to date.

At TABLE OF CONTENTS, PART 5 - CERTIFICATIONS

Delete: 1. Code of Conduct Certifications - Consent to a Criminal Record Verification

Insert: 1. Code of Conduct Certifications - Certification Precedent to Contract Award

At Part 1 - GENERAL INFORMATION, At Article 2 Summary

Delete: Item (ii) in its entirety

Insert:

(ii) Period of Proposed Contract: The contract period will be for five (5) years estimated to start 1 December 2012 to 30 November 2017.

At PART 2 BIDDER INSTRUCTIONS

Delete: Article 1, Standard Instructions, Clauses and Conditions

Insert:

1. Standard Instructions, Clauses and Conditions

The 2003 (2012-07-11) Standard Instructions - Goods or Services - Competitive Requirements, are incorporated by reference into and form part of the bid solicitation.

The text under Subsection 4 of Section 01 - Code of Conduct and Certifications of 2003 referenced above is replaced by:

Bidders should provide, with their bid or promptly thereafter, a complete list of names of all individuals who are currently directors of the Bidder. If such a list has not been received by the time the evaluation of bids is completed, Canada will inform the Bidder of a time frame within which to provide the information. Failure to provide such a list within the required time frame will render the bid non-responsive. Bidders must always submit the list of directors before contract award.

Canada may, at any time, request that a Bidder provide properly completed and Signed Consent Forms (*Consent to a Criminal Record Verification form - PWGSC-TPSGC 229*) for any or all individuals named in the aforementioned list within a specified delay. Failure to provide such Consent Forms within the delay will result in the bid being declared non-responsive.

The text under Subsection 5 of Section 01- Code of Conduct and Certifications of 2003 referenced above is replaced by:

The Bidder must diligently maintain the list up-to-date by informing Canada in writing of any change occurring during the validity period of the bid, and must also provide Canada, when requested, with the corresponding Consent Forms. The Bidder will also be required to diligently maintain the list and when requested, provide Consent Forms during the period of any contract arising from this bid solicitation.

At Part 5 CERTIFICATIONS

Delete: Article 1, Code of Conduct Certifications - Consent to a Criminal Record Verification

Insert::

1. Code of Conduct Certifications - Certifications Required Precedent to Contract Award

- 1.1** Bidders should provide, with their bids or promptly thereafter, a complete list of names of all individuals who are currently directors of the Bidder. If such a list has not been received by the time the evaluation of bids is completed, the Contracting Authority will inform the Bidder of a time frame within which to provide the information. Bidders must submit the list of directors before contract award, failure to provide such a list within the required time frame will render the bid non-responsive.

The Contracting Authority may, at any time, request that a Bidder provide properly completed and Signed Consent Forms (*Consent to a Criminal Record Verification form - PWGSC-TPSGC 229*) for any or all individuals named in the aforementioned list within a specified delay. Failure to provide such Consent Forms within the delay will result in the bid being declared non-responsive.

At PART 7 - RESULTING CONTRACT CLAUSES**At Article 2.1 General Conditions**

Delete: 2035 (2012-07-16), General Conditions - Higher Complexity - Services, apply to and form part of the Contract.

Insert:

2.1 General Conditions

2035 (2012-07-16), General Conditions - Higher Complexity - Services, apply to and form part of the Contract.

The text under Subsection 4 of Section 41 Code of Conduct and Certifications of 2030 referenced above is replaced by:

During the entire period of the Contract, the Contractor must diligently update, by written notice to the Contracting Authority, the list of names of all individuals who are directors of the Contractor whenever there is a change. As well, whenever requested by Canada, the Contractor must provide the corresponding Consent Forms.

At Article 4.1 Period of Contract

Delete: In its entirety

Insert:

4.1 Period of the Contract

The period of the Contract is from date of Contract (estimated to be 1 December 2012) to 30 November 2017 inclusive.

At Article 10, Priority of Documents

Delete: Item (b) in its entirety.

Insert: (b) the general conditions 2035 (2012--07-16) General Conditions - Higher Complexity - Services

At Annex A, STATEMENT OF WORK

At Article 8 Corrective Maintenance Work

Add: Drafting Services	100 hours
Professional Electrical Engineer(s)	30 hours
Electrical Power Systems Coordinator	30 hours

At Appendix II - Scheduled Maintenance Specifications

At PM#4A

Add: Replacement of three Lead filters quarterly (Ships wing, Wildlife live room sink, and 4th floor south)

At PM#12

ADD: An annual inspection to be performed and an annual NDT (Non Destructive Test) by a qualified person.

At PM#15

Add: Thermographic Inspection Equipment List, which is attached.

At PM#17B

Delete: List PM#17B provided at the mandatory site visit.

Insert: List PM# 17B Heating Systems Pumps List which is attached.

At PM#18

Delete: 3. Replace belt as required and hand in old belt to TMU recording exhaust fan serviced

Insert: 3. Replace belt and hand in old belt to TMU recording exhaust fan serviced

At PM#20, At Seasonal Shut-down - November (Before chillers are taken off-line)

Delete: 4. Clean condenser tube bundles and provide eddy-current inspection of condenser tubes. Submit written report indicating results.

Insert: 4. Provide eddy-current inspection of the condenser and evaporator tubes. Submit written report indicating results.

At PM#26 Refrigeration Systems (capacity 5.4 tons/19 KW and up) Annual Leak Check:

Delete: Item 1 in its entirety.

Insert: 1. Conduct a leak test of all of the components of the refrigeration systems or air-conditioning systems listed here that come into contact with a halocarbon.

At PM#27

Delete: The word "three" in the first sentence before packaged.

At PM#32, at Item 1 first sentence

Delete: 28

Insert: 42

At PM#38, at Item 2

Delete: Include lubrication, replacement of belts and filters, cleaning of coils and seasonal start-ups.

Insert: Include leak test, lubrication, replacement of belts and filters, cleaning of coils and seasonal start-ups.

At Annex B, BASIS OF PAYMENT**At Year 1, Year 2, Year 3, Year 4 and Year 5**Delete: **YEAR 1: From 01 October 2012 to 30 September 2013****YEAR 2: From 01 October 2013 to 30 September 2014****YEAR 3: From 01 October 2014 to 30 September 2015****YEAR 4: From 01 October 2015 to 30 September 2016****YEAR 5: From 01 October 2016 to 30 September 2017**Insert: **YEAR 1: From 01 December 2012 to 30 November 2013****YEAR 2: From 01 December 2013 to 30 November 2014****YEAR 3: From 01 December 2014 to 30 November 2015****YEAR 4: From 01 December 2015 to 30 November 2016****YEAR 5: From 01 December 2016 to 30 November 2017****At Article 1.3 Corrective Maintenance Work: On an As and When Requested Basis - Tasks Authorization (TA)**

ADD the following Trades Person to Year 1, Year 2, Year 3, Year 4 and Year 5

Trades Person	Firm Hourly Rate - Regular Hours	Firm Hourly Rate - Overtime (Mon-Sat)	Firm Hourly Rate - Sunday and Statutory Holidays
16. Drafting Services	\$	\$	\$
17. Professional Electrical Engineer(s)	\$	\$	\$
18. Electrical Power Systems Coordinator	\$	\$	\$

At Article 1.4 Mark-Up

Delete: Item b) in its entirety.

Insert:

b) Mark-up, if any, on services, equipment and materials from subcontractors used in the facility in the performance of the Work. _____ %

At Annex F, EVALUATION CRITERIA**At Article 1.1. Mandatory Technical Criteria, Item 2**

Delete: d) On-Site Electrical Power Systems Co-ordinator

Insert: d) Electrical Power Systems Co-ordinator

**At Annex G, CALCULATION OF PRICE FOR EVALUATING PURPOSES ONLY
At Year 1, Year 2, Year 3, Year 4 and Year 5**

Delete: **YEAR 1: From 01 October 2012 to 30 September 2013**
YEAR 2: From 01 October 2013 to 30 September 2014
YEAR 3: From 01 October 2014 to 30 September 2015
YEAR 4: From 01 October 2015 to 30 September 2016
YEAR 5: From 01 October 2016 to 30 September 2017

Insert: **YEAR 1: From 01 December 2012 to 30 November 2013**
YEAR 2: From 01 December 2013 to 30 November 2014
YEAR 3: From 01 December 2014 to 30 November 2015
YEAR 4: From 01 December 2015 to 30 November 2016
YEAR 5: From 01 December 2016 to 30 November 2017

At Article 1.3 Corrective Maintenance Work:

ADD the following Trades Persons to Year 1, Year 2, Year 3, Year 4 and Year 5

Trades Persons	Estimated No. Hours	Firm Hourly Rate Regular Hours	Extended Price
16. Drafting Services	100	\$ _____	\$ _____
17. Professional Electrical Engineers	30	\$ _____	\$ _____
18. Electrical Power Systems Coordinator	30	\$ _____	\$ _____

At Year 1, Year 2, Year 3, Year 4 and Year 5

Delete: **Total for Item 1.3 (Sum of Extended Prices 1 through 15)**

Insert: **Total for Item 1.3 (Sum of Extended Prices 1 through 18)**

Questions and Answers from Mandatory Site Visit and Bidders Conference

- Q1. Pricing, Annex B - will you be sending a revised document to reflect the new start date? Is it available in Excel?
- A1. Annex B will not be amended to reflect the new start date. The revised start date of December 1, 2012 is an estimated date only. The contract when issued will reflect the actual start date. Annex B is not available in excel.
- Q2. SOW, page 25 under General Lighting - can this work be done during working hours?
- A2. The lights that need to be changed in the building are approximately 3,000 per year and 300 ballasts. Sometimes ballasts can be quite high, therefore a lift may be required. Environment Canada (EC) has their own lift, which can be used by the Contractor as long as the Contractor is certified. Work is to done during working hours. EC pays for ballasts and bulbs, however, the contractor is responsible for replacement work.
- Q3. Who is responsible for disposal of ballast?
- A3. There is a light bulb eater in the building which crushes the old bulbs, however the contractor is responsible for disposal of the drum. Ballast disposal will be the responsibility of the contractor.

- Q4. Is there any PCB ballast in the building?
 A4. No PCB ballasts in the building but if any come up, a corrective work order will be put in to cover the disposal.
- Q5. Is there any bid bond required?
 A5. No bid bond is required.
- Q6. Drinking Fountain - is EC supplying the filters?
 A6. No. Contractor will be required to supply filters.
- Q7. What reports are to be generated?
 A7. This is part of the PM Maintenance List. Reports are required for each PM.
- Q8. What is the schedule for the PM?
 A8. The schedule is detailed in the SOW.
- Q9. #26 -it reads 9 months instead of annually - is this a typo?
 A9. No. EC would like this done every 9 months as per the SOW to ensure federal halocarbons requirements are met.
- Q10. Is there any PM for the dock leveler in the warehouse?
 A10. No, this is not included as it is not part of the requirement.
- Q11. Are all 110 Electrical panel labeled?
 A11. Some are labeled. Some will need to be updated and this will be the contractors responsibility. Work can be done Saturday and Sunday or after hours
- Q12. When is work to be done(for corrective maintenance only)?
 A12. Mostly done during working hours unless specified in the TA to be done after h.
- Q13. What are normal working hours?
 A13. Normal working hours are 07:00 to 17:00 hours.
- Q14. Is there a BAS system?
 A14. This is a separate contract
- Q15. Is there any shutdown in the summer?
 A15. No.
- Q16. #15 - Can we have a copy of Thermography and vibration report?
 A16. Yes list of items to be scanned is provided, which is attached.
- Q17. Is it possible to get a copy of the PM report as a sample?
 A17. No, as it is a fairly large document. As an example refer to PM#7 list provided at site visit
- Q18. Who supplies the belts for the roof fans?
 A18. The contractor is responsible for supplying the belts.
- Q19. PM#38 - Does EC provide oils and lubricants for refrigeration?
 A19. The contractor is responsible for oils and lubricants.

- Q20. PM #22 - Volt Distribution Panels - 1/3 of panels to be done at a time - is work to be done after hours?
- A20. There are 400 panels around complex. This work will have to be done after normal working hours or on weekends.
- Q21. What are the lock out procedures?
- A21. It can be ECs procedures or the contractors procedures. However EC will specify this to the contractor.

The following Equipment Lists were provided to Bidders at the Site Visit:

PM#7 CCIW Air Handlers Reference List
 #6A Cogen Cooling Tower
 #6B Chiller Cooling Towers
 Unit Heaters Locations PM#16
 PM #17B Heating Systems Pump
 Roof Fans Locations PM#18
 PM#28 Compressed Air Systems Service Stock List
 PM#33 Lifting Devices Inspection List
 PM\$34 Administration and Lab Building
 PM#38 Refrigeration and Air Conditioning Systems

The following Equipment Lists are provided and attached to this amendment:

List PM# 17B Heating Systems Pumps List.
 PM# 15 Thermographic Inspection Equipment List
 Sample of Vibration Report
 Critical Power Panels, Single Line Diagrams
 Life Safety Panels, Single Line Diagram
 Main Single Line Drawings
 Admin & Lab R&D Boiler Room & Chiller Distribution, Single Line Diagram

Questions and Answers received to date

- Q1 Who is the current incumbent service provider?
- A1. Rondar Inc. Is the current contractor.
- Q2. Who currently provides the janitorial, roads and grounds, elevator, fire detection/suppression and gas detection maintenance/annual certification at this facility and does the possibility exist for these services to be rolled into this contract? Are these services currently coordinated and managed by the TMU?
- A2. No, these services will not be rolled into this contract.
- Q.3 Summary (ii) Pg 4 of 51. The contract period is from 01 Oct, yet the solicitation only closes on the 10 Oct. Allowing time for your bid evaluation, notice of award/negotiations, mobilization and ramp-up should the contract start date not occur later this year?
- A3. The contract start date has been revised to read December 1, 2012, however, this is an estimated date only. The contract when issued will reflect the actual start date.

-
- Q4. Part 7, 1.2.4 Periodic Usage Reports Pg 13 of 51. Is it possible to provide past usage reports (last 2 or 3 years) to provide an idea of the types of work, value of materials, types of rental equipment and if there is a annual pattern to the issuance of TA work? If the Usage Report is a new contract requirement this data can be provided in any other usable format
- A4. The amount of hours under each trade is estimated at Annex A, Article 8 Corrective Maintenance Work. Work will fluctuate and is not guaranteed to be given to the on-site contractor.
- Q5. Part 7, 6.2, 1. Limitation of Expenditure Pg 15 of 51. Can you provide the past total annual value of TA completed in 2011, 2010 and 2009?
- A5. Please refer to the estimates provided at Annex A, Article 8 Corrective Maintenance Work.
- Q6. Annex A, 4 Reporting & Records pg 2 of 46. Does the TMU current use a Computerized Maintenance Management System (CMMS) to manage equipment inventory, work history and current work status? What system is being used?
- A6. The current system we use for corrective work is Access and is for TMU use only
- Q7. Annex A, 5 General Requirements Pg 3 of 46. Is there any way to quantify how much monthly planned work is done outside of normal working hours per year?
- A7. Work done after hours for the corrective work will vary depending on the work. For the scheduled maintenance, after hours work will be mostly for the annual shut-down and PM#22.
- Q8. Annex A, 5 General Requirements Pg 3 of 46 and also Section 9.5 Specifications & Plans pg 5 of 46. There is mention of performing work for other tenants. Can historical values for this work be provided for the last 3 years? Are these other tenants government or are they private industry and can a list be provided?
- A8. Most of the tenants are government departments within the building. Tenants make their own payment which is not charged against this contract. No estimates are available.
- Q9. Annex A, 5 General Requirements Pg 3 of 46. What format are the existing drawings and O&M manuals, AutoCAD, mylar, MSWord or hard copy etc? Since there is no labour charge out rate for this service should one be provided for drafting services, or should it be included in the firm monthly rate? Can an estimated quantity of changes per year be provided.
- A9. Existing drawings are in AutoCAD. We have added drafting services to the trade list for approximately 100 hours annually. Please refer to changes to the RFP detailed above.
- Q10. Annex A, 9.6 Labour Rates. Will the requirements (no tool charges, no vehicle charges, no travel time charges) specified for contractor staff be extended to subcontractors when they are used to provide low volume specialized services on an unscheduled basis, for instance during an emergency call out?
- A10. No, requirements will not be extended to subcontractors.
- Q11. Annex A, D2 and Appendix I. Can additional equipment details (make/model/quantities) and a site plan and building drawings that show the location of the equipment be provided?

-
- A11. Equipment lists were provided at the site visit.
- Q12. Annex F, 1.1 Mandatory Technical Criteria, 2. The evaluation criteria states Professional Electrical Engineers and On-Site Electrical Power Systems Coordinator, however neither Appendix I or II call up these position requirements. Furthermore Annex B Basis of Payment does not provide for these positions unless they are rolled into the annual shut-down and/or firm monthly rate.
- A12. The positions should be available on an as required basis but don't have to be on site. These position have been added to the trades as detailed in the revision above.
- Q13. Annex B, Basis of Payment 1.4 Mark-Up, a). Can we indicate separately the contractors mark-up on materials provided by subcontractors in the provision corrective maintenance work on TA's.
- A13. The contractors mark up on subcontractors should be on the total subcontractors invoice.
- Q14. Does the contractor or the TMU coordinate with Ontario Hydro and/or the local municipality for the high voltage shut-down and who pays the corresponding fees?
- A14. Scheduling and fees will be the responsibility of the contractor.
- Q15. Can current single line electrical drawings be provided for bidding?
- A15. Yes. Drawings are attached.
- Q16. Can a past annual electrical report be provided as an example of the format, extent of information etc., for bidding.
- A16. The SOW details what is needed for the reports. The amount of equipment is provided in the single line drawings.
- Q17. The RFP closing date is stated as Oct. 10, 2012 @ 02:00pm on page 1 of 51 of the document. The contract start date is stated as (estimated) to start Oct. 1, 2012 in Part 1, General Information Section 2.(ii). Please confirm the RFP closing date.
- A17. The contract start date has been revised as detailed in the changes above. There is no change to the RFP closing date.
- Q18. We would like to return on site with our HVAC subcontractor and our Substation Maintenance Provider to review the site - who can we contact to arrange a 1 hour tour ?
- A18. The Mandatory Site Visit was held on September 11, 2012. Bidders will not be given another appointment.

-
- Q19.** Please advise if Glycol and Refrigerant supply costs for the HVAC equipment category are to be included or if it is an extra to this maintenance proposal.
- A19.** Under **PM#39** Glycol loops, it states that the contractor will be using building stock for glycol. **PM#38** heading 2 we are changing it to read: include leak test, lubrication, replacement of belts and filters, cleaning of coils and seasonal start-ups. Which means the leak test will be included but if refrigerant is needed, it will be covered under a corrective work order.

All other terms and conditions remain unchanged.

PM# 17B HEATING SYSTEMS PUMPS

	PUMPS	LOCATION	# OF PUMPS	Comments
1	A&L HW	A&L 3rd	2	
2	A&L Glycol	A&L 3rd	2	
3	Induction	A&L 3rd	1	
4	A&L Rad	A&L 3rd	1	
5	A&L Terminal Reheat	A&L 3rd	1	
6	System#21	A&L 3rd	1	
7	System#27	A&L 3rd	2	
8	System#28	A&L 3rd	2	
9	System#31	A&L 3rd	4	
10	A&L CONDENSATE	A&L 3rd	2	
11	Ultra Trace Glycol	A&L PH	2	
12	Cogn HX PH	A&L PH	1	
13	System#2	R&D PH	1	
14	System#4	R&D PH	1	
15	W.W Rad	R&D PH	1	
16	W.W Unit Heater	R&D PH	1	

17	System#6 Reheat	R&D PH	1	
----	-----------------	--------	---	--

	PUMPS	LOCATION	# OF PUMPS	Comments
18	R&D Rad Zone	R&D PH	1	
19	R&D HW	R&D PH	2	
20	R&D Glycol	R&D PH	2	
21	Ecotox Glycol	R&D PH	1	
22	System#3	R&D PH	1	
23	System#5	R&D PH	1	
24	R&D CONDENSATE	R&D PH	2	
25	SYSTEM#1	R&D PH	2	
26	System#11	W.W Roof	1	
27	System#12	W.W Roof	1	
28	System#41HCP	H246	1	
29	HYD Rad CP	H246	1	
30	HYD Lab RHTP	H246	1	
31	System#53	WTC	1	
32	System#55	WTC	1	
33	System#56	WTC	1	

34	System#57	WTC	1	
35	WTC Glycol	WTC PH	2	P105,P106
36	WTC RAD	WTC PH	1	

	PUMPS	LOCATION	# OF PUMPS	Comments
37	WTC HCP	WTC PH	1	
38	WTC DHW CIRC	WTC PH	1	
39	WTC CONDENSATE	WTC BASEMENT	2	
40	COGN P1	BOILER ROOM	1	
41	FEEDWATER	BOILER ROOM	3	
42	CONDENSATE	BOILER ROOM	2	
43	DHW CIRC	BOILER ROOM	1	

Thermographic Inspection Equipment List

Outdoor Substation

Main Incoming Pole
Outdoor Main Switchgear
Main Transformers
Cable from Transformer to Main Substation

Boiler Room Substation – Main 600V Distribution T1 & T2

A&L Main Distribution
Critical Power Supply – 1
Life Safety Splitter – 1
R & D Distribution
Capacitor Distribution
Main T1
Chiller Distribution
Main T2
Boiler Room Distribution
Chiller Distribution
R & D
A & B Main Disconnect
Capacitor Distribution
Synchronizing Breaker
Portable Generator
Co-Gen Breaker
Main Critical Power Panel CCP – 1
Life Safety Splitter # 1

Boiler Room Substation – Main 600V Distribution Substation New Boiler SWBD

Hydraulics Lab Bus Duct
Spare
MCC-1
Tie Breaker
Hydraulics Lab MCC-9
Boiler Room Distribution Panel
Panel DPW
Main Critical Power Panel CPP-1
Critical Power Panel CPP-2
T1 A – Capacitor Bank & FD's
T1 B – Capacitor Bank & FD's
T2 A – Capacitor Bank & FD's
T2 B – Capacitor Bank & FD's
Life Safety Splitter # 1
Life Safety Panel 1 – LSP 1
Life Safety Panel 2 – LSP 2
30kVA TX Panel 2 – LSP 2
120 / 208V Distribution Panel 2 – LSP2
Boiler Room 120 / 208V Distribution
Exhaust Fan RFX – 1 1.5 HP

Boiler Room Floor

Boiler 1 Square D FD by Control, 600V 3Ø 30A
Boiler 2 Square D FD by Control, 600V 3Ø 30A
Boiler 3 Square D FD by Control, 600V 3Ø 30A
Funas 1 Panel, 600V 3Ø 600A
Funas 2 Panel, 600V 3Ø 600A
Main Breaker 1, 600V 3Ø 600A
Main Breaker 2, 600V 3Ø 600A
Tie Breaker, 600V 3Ø 1,600A
Chiller 1, 600V 3Ø 1,600A
Chiller 2, 600V 3Ø 1,600A
Circulating Pump # 2
Circulating Pump # 1
MCC1 Various Starters

Thermographic Inspection Equipment List

MCC1A Various Starters

Thermographic Inspection Equipment List

Boiler Room Lower Level

Fire Pump Control, 600V 3Ø 150A 50HP
Splitter, 600V 3Ø 100A
Square D FD 1, 600V 3Ø 60A
Square D FD 2, 600V 3Ø 60A
Square D FD 3, 600V 3Ø 60A
ITE FD No. Identification, 600V 3Ø 60A
LP-BD
MCC2 Various Starters
MCC101 Various Starters

Boiler Room West Wall

Moeller FD EF 606, 600V 3Ø 30A
Moeller FD EF 607, 600V 3Ø 30A
Moeller FD EF 608, 600V 3Ø 30A
Moeller FD EF 609, 600V 3Ø 30A

Boiler Room South Wall

Air Compressor # 1
Air Compressor # 2
Air Compressor # 3
460V Splitter
1,125kVA 600 / 460 Transformer
Square D 600V 200A Switch
112kVA Transformer 600 / 460V
Splitter
Square D 60A Switch

Boiler Room – Upper Level North Wall

R.O. Feed
R.O. Central Panel
PP2
PP3

Boiler Room – Upper Level East Wall

LP-B3
30kVA 30A FPE Disconnect
30kVA Transformer

Hydraulic Area

Power Panel No. 1, 600V 3Ø 200A
Westinghouse
FPE LP, 120 / 208V
LP 600 / 347V, 225A
Hammond 45kVA Transformer, 600V 3Ø 347V

2nd Floor H246

150kVA Transformer, 600V 3Ø 347V
LDP1 Various MCB, 120 / 208V 800A
LP 1K, 110 / 208V 100A
Relay Panel – R9
Square D FD No. Identification, 600V 3Ø 30A
MCC 9 Various Starters

New Wet Lab Mezzanine

CB-1
P1
Panel DPW
400A Transfer Switch
Panel DPEWL
SF-1
EF-1
Panel-EFA
Panel-EPA
75kVAT x 600/208
EF-2

Thermographic Inspection Equipment List

P-2

SF1-P3C

SF1-P4C

Panel 1G

Panel 1F

Fed from Panel LP-EPA

Cooler 2

Cooler 1

R & D Substation

MCC 3 Breaker, 600 3Ø 600A

WW 450kVA Transformer Breaker, 600V 3Ø 600A

Main Breaker 1, 600V 3Ø 800A

MCC 4 Breaker, 600V 3Ø 600A

Tie Breaker, 600V 3Ø

Main Breaker 2, 600V 3Ø 800A

Spare

Main 600V WW Breaker, 600V 3Ø 600A

R & D 450kVA Transformer North Wall

Main 600V Workshop Warehouse Distribution Panel

WW 450kVA Transformer, 600V 3Ø 120/208V

MIRUS 75kVA Transformer LP-R8, 208V 208A

MIRUS 75kVA Transformer LP-R1, 208V 208A

FPE Panel 600V Distribution, 600V 3Ø 100A LSP-3

45kVA Transformer 600 – 208Y / 120 LSP-3

200A Contactor for Critical Power Panel CPP – 3

R & D Critical Power Panel CPP – 3

TX for CRP – 2 600 / 208V

Panel CRP – 2 120 / 208V

200A 120 / 208V Distribution LSP-3

R & D 450kVA Transformer, 600V 3Ø 120 / 208V

FPE Panel R & D North End, 120 / 208V 1,600A

MCC3 Various Starters

R & D Penthouse Outside Substation

Siemens FD

Hammond 45kVA Transformer, 600V 3Ø 120 / 208V

R & D Penthouse Centre

Siemens FD R245 Power Panel, 208V 3Ø 200A

Moeller KM0080W21102D, 209V 3Ø 222A

Siemens UPS 208 Power Supply, 208V 3Ø 400A

FP 208 UPS Main Power, 208V 3Ø 400A

BEL Splitter, 600V 400A

Siemens FD No Identification, 208V 3Ø 60A

Siemens Load Centre Panel, 120 / 240V 3Ø 100A

Hammond Transformer, 600V 3Ø 120 / 208V 3Ø

Square D – R245 UPS

R & D Penthouse South End

Square D FD, 600V 3Ø 100A

FP FD Chiller # 2, 600V 3Ø 100A

FP FD Hot Water Circulating Pump, 600V 3Ø 30A

FP FD Circulating Pump 1, 208V 3Ø 30A

FP FD Circulating Pump 2, 208V 3Ø 30A

Square D FD Cold Water Recirculating, 600V

CEL Splitter, 208V 3Ø 225A

MCC4 Various Starters

Administration and Lab Substation – Main 600V Switchboard

MCC No. 7 Breaker, 600V 3Ø 600A

South Distribution Breaker 600V 3Ø 1,600A

Main Breaker Supplied from Transformer 1,600V 3Ø 1,600A

MCC 8 Breaker, 600V 3Ø 600A

Thermographic Inspection Equipment List

Tie Breaker, 600V 3Ø 1,600A

Main Breaker supplied from Transformer 2,600V 3Ø 1,600A

PP1 Breaker, 600V 3Ø 600A

Main Lac Emergency Distribution, 600V 3Ø 600A

MCC 6 Breaker, 600V 3Ø 1,600A

North Distribution Breaker, 600V 3Ø 1,600A

Administration and Lab Substation – 120/208 South Distribution – Life Safety Panel

LSP-4 600V 400A Distribution

Emergency North 150kVA 600 / 208Y / 120 Transformer

Emergency North 120 / 208 800A Distribution

Disconnect 1

Disconnect 2

Splitter

112kVA Transformer fed from MCC8

LDP-1, 2, 3 & 4

Main Disconnect for UPS for L727

LDP1 South West Breaker, 600V 3Ø 1,600A

LDP2 South East Breaker, 600V 3Ø 1,600A

208V Bus Duct South East Breaker, 600V 3Ø 600A

208V Bus Duct South West Breaker, 600V 3Ø 600A

1,000kVA Transformer, 600V 3Ø 120/208V

208V Bus Duct North East Breaker, 600V 3Ø 600A

400A Contactor 600V Feed for Critical Power Panel CPP – 4

A & L Critical Power Panel CPP – 4

CRP – 3 600V – 120 / 208V TX

Panel CRP – 3

LDP3 North West Breaker, 600V 3Ø 1,600A

LDP4 North East Breaker, 600V 3Ø 1,600A

208V Bus Duct North West

Administration and Lab – 3rd Floor

Siemens FD Atlas Compressor 1, 600V 3Ø 60A

Siemens FD Compressor 3, 600V 3Ø 60A

MCC6 Various Starters

MCC7 Various Starters

MCC8 Various Starters

Administration and Lab– 3rd Floor Outside Substation

Siemens FD Computer Room Emergency, 600V 3Ø 200A

Siemens FD LP 1P Training Room, 600V 3Ø 60A

Square D Compressor Room Power Supply, 600V 3Ø 100A

Splitter, 600V 3Ø 400A

75kVA Transformer, 600V 3Ø 120 / 208V

4th Floor North Service Corridor

West Bus Duct, 600V 3Ø

East Bus Duct, 600V 3Ø

Panel LDP – E2, 120 / 208V 3Ø 225A

4th Floor South Service Corridor

West Bus Duct, 600V 3Ø

East Bus Duct, 600V 3Ø

Panel LDP – E1, 120 / 208V 3Ø 225A

Penthouse

FPE Panel LDP – 8, 120 / 208V 3Ø

LP-8A, 120 / 208V 3Ø

Panel – E1, 600V 3Ø 225A

Westinghouse 225kVA Transformer, 600 / 208V 3Ø

Square D FD EF 154, 208V 3Ø 30A

FPE FD for MCC BJ, 208V 3Ø 60A

Cutler Hammer FD EF 107A, 1,208V 3Ø 30A

FPE FD for MCC B1, 208V 3Ø 60A

FPE FD for MCC BH, 208V 3Ø 60A

Thermographic Inspection Equipment List

FPE FD for MCC BH, 208V 3Ø 60A
FPE FD for MCC BF, 208V 3Ø 60A
Square D FD EF 26C, 208V 3Ø 30A
FPE FD EF 136, 208V 3Ø 30A
FPE FD for MCC BA, 208V 3Ø 30A
Square D FD EF 27A, 208V 3Ø 30A
FPE FD EF 164, 208V 3Ø 30A
FPE FD for MCC BB, 208V 3Ø 30A
Square D EF 137, 208V 3Ø 30A
Westinghouse FD EF 146, 208V 3Ø 30A
FPE FD for MCC BC, 208V 3Ø 60A
Westinghouse FD EF 147, 208V 3Ø 30A
FPE FD for MCC BD, 208V 3Ø 60A
Square D FD EF 47 / L634, 208V 3Ø 30A
Square D FD EF 17D, 208V 3Ø 30A
FPE FD EF 17D, 208V 3Ø 30A
FPE FD for MCC AD, 208V 3Ø 60A
Square D FD EF 167, 208V 3Ø 30A
Square D FD EF 17B, 208V 3Ø 30A
Westinghouse FD EF 166 / L730, 600V 3Ø 30A
Square D FD EF 16B, 208V 3Ø 30A
Square D FD EF 16, 208V 3Ø 30A
Square D FD EF 138, 208V 3Ø 30A
FPE FD for MCC AC, 208V 3Ø 60A
Square D FD EF 134, 208V 3Ø 30A
FPE FD for MCC AB, 208V 3Ø 60A
AB FD EF 4 / L407, 208V 3Ø 15A
FPE FD for MCC AA, 208V 3Ø 60A
Klockner Moeller EF2, 208V 3Ø 15A
Panel HVP – 8A, 600V 3Ø
FP FD for MCC AE, 208V 3Ø 60A
FP FD EF 132, 208V 3Ø 30A
FP FD EF 54, 208V 3Ø 30A
FP FD for MCC AF, 208V 3Ø 60A
Rex. Transformer 600/208V 3Ø 60A
FP FD for MCC AG, 208V 3Ø 60A
Cutler Hammer FD, 208V 3Ø 30A
FP FD for MCC AH, 208V 3Ø 60A
FP FD for MCC AI, 208V 3Ø 60A
Cutler Hammer FD P1, 208V 3Ø
FPE Disconnect for MCC AJ, 208V 3Ø 60A
Cutler Hammer FDUT EF1 EFC 4500 0P09, 600V 3Ø
Cutler Hammer FD P2, P3, 208V 3Ø
FPE Disconnect for MCC AK, 208V 60A
Square D FD EF 153, 208V 3Ø 30A
FPE FD for MCC BL, 208V 3Ø 60A
FPE FD for MCC BK, 208V 3Ø 60A
Square D FD EF 152, 208V 3Ø 30A
EF-19 L604
EF-18 L404
LP-8E Bk10
LP-8E
PP-E1
AI – Booster Supply Fan North
BI – Booster Supply Fan South
LI-ED35A Zone 3
Interconnecting Wiring
EI-EF17A Zone 2
FI-EF42A Zone 1 & 2

Thermographic Inspection Equipment List

GI-EF47A Zone 1

HI-EF48A

Transformer Westinghouse 30kVA 600 208/1120

MCC AA Various Starters

MCC AB Various Starters

MCC AC Various Starters

MCC AD Various Starters

MCC AE Various Starters

MCC AF Various Starters

MCC AG Various Starters

MCC AH Various Starters

MCC AI Various Starters

MCC AJ Various Starters

MCC AK Various Starters

MCC BA Various Starters

MCC BB Various Starters

MCC BC Various Starters

MCC BD Various Starters

MCC BE Various Starters

MCC BF Various Starters

MCC BG Various Starters

MCC BH Various Starters

MCC BI Various Starters

MCC BJ Various Starters

MCC BK Various Starters

MCC BL Various Starters

Machine Shop Area

Panel WWDP – 1, 120 / 208V 3Ø 800A

Panel WWDP – 2, 600V 3Ø 800A

Hammond 45kVA Transformer, 600V 3Ø 347V

347 LP, 347 / 600V 225A

MCC 5 Various Starters

Machine Shop Room W108

Fed from WWDP-1 FD's

LP-W3

LP-W3 Contactor

EF-412

EF-415

Fed from WWDP-2

Boat Shop Overhead Door

PP-W3

Panel PP – W2, 600V 3Ø 400A

FPE Switch, 600V 3Ø 400A

FPE FD, 120 / 208V 3Ø 200A

LP – W2, 120 / 208V 3Ø 225A

Machine Shop 107-B

LPW4A

LP-W4 FD's

LP-W4

PP-W4 FD's

PP-W4

Warehouse

Feeder WW Main 600V Disconnect

Tx No. 1 Finger Docks Disc. No. 8

Tx No. 2 Finger Docks Power

Tx No. 3 Finger Docks Disc. No. 7

Feeder PP WB

LR-W14

PP-W8

Thermographic Inspection Equipment List

Splitter

Boat Shop

PP – W5 Disconnect, 600V 3Ø 400A

Panel PP – W5, 600V 3Ø 400A

Wall Mount Transformer, 600V 3Ø 120 / 240V

LP – W5, 120 / 240V 100A

FPE FD No Identification, 240V 100A

FPE FD, 600V 3Ø 30A

LP – W6, 120 / 240V 225A

2nd Floor Electrical Room W230

WW Disconnect Panel 1, 120 / 208V 600A

Rex 225kVA Transformer, 600V 3Ø 120 / 208V

WW PP1, 600V 3Ø

Rex 45kVA Transformer, 600V 3Ø 120 / 208V

Panel D, 208 208/225A

Emergency Power WWE6 208 / 120V 3Ø

MCC 12 Various Starters

MCC 13 Various Starters

2nd Floor Electrical Room W245

45kVA Transformer, 600V 3Ø – 208 / 120V

Siemens FD W239EF, 240V 3Ø 30A

Siemens FD W251A, 600V 3Ø 30A

Siemens FD W251B, 600V 3Ø 30A

Siemens FD, 600V 3Ø 30A Compressor # 1

Siemens FD W236 EF, 240V 3Ø 30A

Siemens FD W239 EF, 240V 3Ø 30A

Siemens FD W238 EF, 240V 3Ø 30A

Square D FD, 600V 3Ø 60A

2nd Floor Electrical Room W245 (Within W250)

MCC 14 Various Starters

Waste Water Technology Centre (WTC)

PDF-1 Switchboard

600V Distribution

Life Safety Panel Transfer Switch

WTC Penthouse Life Safety Panel LSP-5 600V 225A

Tx for LP-E LP-EB 600V 120/208V LSP-5

Marcus Transformer 150kVA 600V 208/120

60A Disc. Ground Floor WTC High Bay Splitter

200A Contactor 600V Feed WTC Penthouse Critical Power

200A Disc.

Exhaust Fan No. 2 West Strobic No. 1

Exhaust Fan No. 1 West Strobic No. 1

Map Pilot Plant Mezz.

Sewage Pumps

Panel UP

Control Panel for Condensate Pump No. 1 & No.2 in Tunnel WTC

Panel LP-E2 Zenon Pump

Spare

WTC Penthouse Critical Power CPS-5

WTC Penthouse East Side

MCC 11 Various Starters

Outside H-241


Supply Fan S3

Return Fan S3


Splitter for S3

Relay panel R10

Splitter for Relay Panel R10





CUSTOMER		CANADA CENTER FOR INLAND WATERS	
TITLE		CRITICAL POWER PANELS SINGLE LINE DIAGRAMS	
PROJECT NO.		R26 - 335	
SHEET		4 OF 4	
DATE		06/06/12	
DESIGNER		RND	
CHECKED BY		RND	
SCALE		NOT TO SCALE	



REVISIONS		DATE	APPROVED
1	REV CHANGES	06/04/12	

OWNER		CANADA CENTER FOR INLAND WATERS	
TITLE		LIFE SAFETY PANELS SINGLE LINE DIAGRAM	
PROJECT NO.		R26-335	
SHEET NO.		3 OF 4	
DRAWN BY: R.A.		CHECKED BY: R.A.	
DATE: 06/04/12		SCALE: NOT TO SCALE	





MACHINERY RELIABILITY REPORT

Inland Waters Annual Vibration Survey

FOR DATA COLLECTED AT INLAND WATERS ON SEPTEMBER 30, 2011

NIS – (Not in service (previous report (if any) left for trending and your information)

OK – (Unit operating within spec for this run speed and application)

Warning – (1st alarm level – usually tagged for trending and no usually action required)

Alert – (Reached low alarm level – extra data gathered for analysis - may require visual inspection)

Fault – (Exceeded one or more alarms – may require immediate attention and/or replacement)

EQUIPMENT	STATUS	FINDINGS	NOTES - SUGGESTIONS
SYSTEM # 28 FANS & MOTORS			
#28 Supply Fan & Motor	OK	Everything seems to have settled in nicely on this unit since installation and balancing.	Slight axial movement but not of concern at this time and lower than previous readings.
#28 Return Fan & Motor	OK	Fan and Motor operating within spec as related to vibration for this run speed and application.	(Fan bearing access only via grease nipples). Continue to monitor machinery reliability (vibration) on regular basis.
SYSTEM #31 FANS & MOTORS			
#31 Supply Fan & Motor	OK	Fan and Motor operating within spec as related to vibration for this run speed and application.	Continue to monitor machinery reliability (vibration) on regular basis.
#31 Return Fan & Motor	OK	Fan and Motor operating within spec as related to vibration for this run speed and application.	Continue to monitor machinery reliability (vibration) on regular basis. Note: No access to non-drive-end bearing. Permanent mounted accelerometer wired to a termination box for future checks suggested.
SYSTEM #27 FANS & MOTORS			
#27Supply Fan & Motor	Warning	Same as 2009 findings: Some early bearing activity at fan non-drive-end.	Tagged for trending purposes only and for comparison to next collected data at next survey – no action required.
#27 Return Fan & Motor	OK	Fan and Motor operating within spec as related to vibration for this run speed and application.	Continue to monitor machinery reliability (vibration) on a regular basis.
SYSTEM #1 FANS & MOTORS			
Machine	Status	Findings	Notes
#1 Supply Fan & Motor	OK	Fan and Motor operating within spec as related to vibration for this run speed and application.	Continue to monitor machinery reliability (vibration) on a regular basis.

#1 Return Fan & Motor	OK	Fan and Motor operating within spec as related to vibration for this run speed and application.	Continue to monitor machinery reliability (vibration) on a regular basis.
SYSTEM #5 SUPPLY FAN & MOTOR			
#5 Supply Fan & Motor	Warning	Fan: Early bearing activity at fan non-drive-end. Motor: Increased vertical vibration at drive end of motor.	Fan: Tagged for trending purposes will compare to next survey – no action required. Motor: Inspect belt tension and hold down hardware.
SYSTEM #25 ADMIN FAN & MOTOR			
#25 Supply Fan & Motor	OK	Fan and Motor operating within spec as related to vibration for this run speed and application.	Continue to monitor machinery reliability (vibration).
#25 Return Fan & Motor	Not checked for 2011 OK	(2010 report) Fan and Motor operating within spec as related to vibration for this run speed and application.	Continue to monitor machinery reliability (vibration).
SYSTEM #23 AUD SUPPLY FANS & MOTORS			
#23 Supply Fan & Motor	Warning	Motor operating within spec as related to vibration for this run speed and application.	Warning status for early bearing outer race activity at fan non-drive-end.
#23 Return Fan & Motor	OK	Fan and Motor operating within spec as related to vibration for this run speed and application.	Continue to monitor machinery reliability (vibration).
SYSTEM #52 SUPPLY FAN & MOTOR			
#52 Supply Fan & Motor	OK	Fan and Motor operating within spec as related to vibration for this run speed and application.	Continue to monitor machinery reliability (vibration).
SYSTEM #6 SUPPLY MALL FAN & MOTOR			
#6 Supply Fan & Motor	OK	Fan and Motor operating within spec as related to vibration for this run speed and application.	Continue to monitor machinery reliability (vibration).