

The following changes are effective immediately and shall be incorporated into the Contract Documents.

MECHANICAL SPECIFICATIONS

Section 23 73 10 - Air Handling - Built-Up

- .1 Add Item 2.1.9 as follows: "Individual modular sections and components shall be sized to fit through 800 mm wide door opening."
- .2 Add Item 2.1.10 as follows: "Maximum allowable dimensions of assembled air handling unit: 4191 mm long x 711 mm wide x 1321 mm high."

Section 23 81 24 - Air Conditioning Split Systems

- .1 Revise Item 2.4.2.5 to read: "Accessories to permit operation down to -5°C."
- .2 Clarification: Condensing units specified under Item 2.2 pertain to air handling units WW18-AHU1 and WW18-AHU2. Condensing units specified under Item 2.4 pertain to ductless split evaporator units specified under Item 2.3.
- .3 Clarification: Ductless split systems are intended to be stand-alone systems independent of the EMCS.

MECHANICAL DRAWINGS

DRAWING M-10

- .1 Clarification: In "HVAC Unit Schedule", hydronic heating coil serving WW19-HRV1 shall be duct mounted. Refer also to drawing M-08 for approximate location of coil.

END OF ADDENDUM No. 2