

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
 Bid Receiving Public Works and Government  
 Services Canada/Réception des soumissions/Travaux  
 publics et Services gouvernementaux Canada  
 The Cambridge Building  
 3 Queen Street/3, rue Queen  
 Charlottetown  
 Prince Edward Island  
 C1A 4A2

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

All enquiries are to be submitted in writing to the Contracting Authority, Darlene Reay, either by facsimile or by e-mail at:  
 darlene.reay@pwgsc.gc.ca.

### Vendor/Firm Name and Address

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

### Issuing Office - Bureau de distribution

Public Works and Government Services Canada  
 The Cambridge Building  
 3 Queen Street/3 rue, Queen  
 PO Box 1268/CP 1268  
 Charlottetown  
 Prince Ed  
 C1A 4A2

<b>Title - Sujet</b> Structure 406 Repairs, Launching	
<b>Solicitation No. - N° de l'invitation</b> E0226-122949/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b> R.050638.001	<b>Date</b> 2012-03-09
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWC-008-3062	
<b>File No. - N° de dossier</b> PWC-1-34206 (008)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-03-16</b>	<b>Time Zone</b> Fuseau horaire Atlantic Standard Time AST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Reay, D (PWC)	<b>Buyer Id - Id de l'acheteur</b> pwc008
<b>Telephone No. - N° de téléphone</b> (902) 566-7518 ( )	<b>FAX No. - N° de FAX</b> (902) 566-7514
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

This Addendum is raised to provide the following answers to questions provided by bidders.

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

### **ANSWERS TO QUESTIONS**

1. **QUESTION**

Why is the new deck to be double spiked ?

**ANSWER**

It was a design decision to double spike the new decking.

2. **QUESTION**

Why is the front bottom wale being removed, the elevation of the deck is not changing and you are only lowering the bottom wale 75mm?

**ANSWER**

The top wale must be lowered to accommodate the new pile cap. The bottom wale must also be lowered so that there will not be a requirement to drill new holes in the fenders or wale.

3. **QUESTION**

Provide the model or size of the mooring cleat.

**ANSWER**

Details of the mass/size/shape and material type for the mooring cleat is provided on Detail 3/M2 of the contract drawings and in paragraph 2.4 in Section 05 50 00 - Metal Fabrications of the contract specification.