

V:\01691\ACTIVE\140010092\DESIGN\DRAWINGS\ELECTRICAL\WORKING\140010092_E-700.DWG
8/22/2012 3:50 PM

	2P	31	1259 600	600	32	15A	005 AND 006 4 RECEPTS -RMS. 004, 005 AND 006
DOOR OPERATOR	15A	33	1000 600		34	15A	4 RECEPTS -RM 006
DOOR OPERATOR	15A	35		1000 600	36	15A	4 RECEPTS -RMS. 006 AND 007
3 RECEPTS -2 GFI/WP AND 1 IN VESTIBULE	15A	37	450 1000		38	15A	DOOR OPERATOR
2 RECEPTS GFI/WP	15A	39		600 1000	40	15A	DOOR OPERATOR
DHW-1	15A	41		300 187	42	15A	HWP-1
F/A CONTROL PANEL	15A	43	450		44	15A	3 RECEPTS (GFI) RMS. 008 AND 009
SPARE	15A	45		500	46	20A	1 GFI RECEPT. -KITCHEN
20KVA UPS CABINET	100A	47		3000 500	48	20A	1 GFI RECEPT. -KITCHEN
	2P	49	3000 600		50	15A	FRIDGE - KITCHEN
2 RECEPTS (GFI) W/R's 005A AND 013	15A	51		500 200	52	15A	ELECTRONIC FAUCETS W/R's 018 AND 019
2 RECEPTS (GFI) W/R's 018 AND 019	15A	53		500	54		
F/A ANNUNCIATOR PANEL	15A	55			56	30A	TVSS
UH-1	15A	57		1248	58		
	2P	59		1248	60	3P	
2 GFI RECEPTS ROOFTOP	15A	61	500 250		62	15A	1 GFI RECEPTS ROOFTOP
1 GFI RECEPT ROOFTOP	15A	63		250	64		
		65			66		
		67			68		
		69			70		
		71			72		
		73			74		
		75			76		
		77			78		
		79			80		
		81			82		
		83			84		
PHASE LOADS			15560	12689	14132	PANEL LOAD = 42381 WATTS	
TYPE	VOLTAGE	MAINS	BREAKER I.C. (AMPERES)		<div><div><input checked="" type="checkbox"/> MAIN BREAKER</div><div><input type="checkbox"/> FLUSH</div><div><input checked="" type="checkbox"/> SURFACE</div><div><input type="checkbox"/> FEED-THRU LUGS</div><div><input checked="" type="checkbox"/> C/W LOCKING COVER</div></div> <div><div><input type="checkbox"/> HINGED TRIM</div><div><input type="checkbox"/> I.C. BUS</div><div><input checked="" type="checkbox"/> SPRINKLER PROOF</div><div><input type="checkbox"/> DBL. NEUTRAL</div><div><input checked="" type="checkbox"/> TVSS</div></div>		
<input type="checkbox"/> NBLP	<input type="checkbox"/> 208V, 3ø,3W	<input type="checkbox"/> 100A	<input type="checkbox"/> _____ kA				
<input type="checkbox"/> NHDP	<input checked="" type="checkbox"/> 120/208V, 3ø,4W	<input checked="" type="checkbox"/> 225A					
<input type="checkbox"/> NBDP	<input type="checkbox"/> 600V, 3ø,3W	<input type="checkbox"/> 400A	<input checked="" type="checkbox"/> NEW PANEL				
<input type="checkbox"/> CDP	<input type="checkbox"/> 347/600V, 3ø,4W	<input type="checkbox"/> _____ A	<input type="checkbox"/> EXISTING PANEL				

AUG. 2012
140010092

ORIGINAL SHEET - ANSI A



Stantec Consulting Ltd.
100-401 Wellington Street West
Toronto ON Canada
M5V 1E7
Tel. 416.596.6666
Fax. 416.596.7892
www.stantec.com

Client/Project
BCI
FINANCE AND PAROLE
BUILDING

Figure No.

SK-8

Title

PANELBOARD SCHEDULE