

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet General Purpose Bldg-N.B./N.S.	
Solicitation No. - N° de l'invitation EC016-123090/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client R.043958.001	Date 2012-04-10
GETS Reference No. - N° de référence de SEAG PW-\$PWB-007-3063	
File No. - N° de dossier PWB-1-34209 (007)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-05-10	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ellis-Herring , Alison PWB	Buyer Id - Id de l'acheteur pwb007
Telephone No. - N° de téléphone (506) 636-3908 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Solicitation Amendment Number Six (6) is raised to include the following addendum.

The following Addendum to the tender documents is effective immediately. This Addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 6

1. EXTENSION

Notice is hereby given that the time for the reception of tenders previously due April 24, 2012 is hereby extended to 14:00, May 10, 2012.

All enquiries must be submitted in writing to the Contracting Authority no later than May 1, 2012. Enquiries received after that time may not result in an answer being provided.

2. TERMS OF REFERENCE

- .1 **Delete** from Section 1.6.2: Item 1.0 - 100% Working Drawings Completion Date of July 5th, 2012,

and replace with :

Item 1.0 100% Working Drawings – Completion date – July 27th, 2012.

- .2 **Delete** Section 5.3.1.5.a. (page 83 of 188), **and replace with** revised Section 5.3.1.5 a. To read:

“The building envelope: Any cladding must provide for an efficient barrier against rain penetration. The design is to incorporate as many means as possible to shed water away from the wall surfaces.”

3. TECHNICAL CONSIDERATIONS - GO AND GI PROJECTS

- .1 **Delete** Section SP-2 - Fence in its entirety.
- .2 **Delete** Section SP-6 - Site – Temporary Construction & Temporary Secured Construction **and replace with** Section SP-6 Site – Temporary Construction & Temporary Secured Construction, Revised April 2012 (attached as ATT 11) .

.3 **Delete** Section SU - Site Utilities **and replace with** Section SU - Site Utilities, Revised April 2012 (attached as ATT 12).

4. **DRAWINGS**

Delete drawings numbered A-1, A-2, A-3 and A-4 **and replace with** the drawings numbered G.I.- Floor Plans, G.O. - Floor Plans, G.I.-G.O. - Door Styles and G.I.- G.O.- Millwork. The drawings are attached as ATT 13.

5. **SOLICITATION AMENDMENT NUMBER 4**

Q27 – Auto CAD Drawings: **Change** – Auto CAD drawings will **NOT** be provided.

6. **QUESTIONS AND ANSWERS**

Q1. Energy performance of the buildings. Corrections Services Canada requires the energy usage not to exceed 1400 MJ/m2/year based on a national average 4,700 Heating Degree-Days (HDD), PWGSC – 1000 MJ/m2/year (based on local Heating Degree Days, Renous HDD – 5000, Springhill HDD - 4600). To which energy performance do we design?

A1. Design to 1000 MJ/m2/year based on local heating degree days (HDD)

Q2. PWGSC - There is a reference for gas heating of the domestic hot water, assuming this does not apply to Springhill as we are using the district heating system.

A2 Springhill is using the district heating system

Q3. Springhill – assuming level 1 Multi Purpose Room 2 is mislabeled as “Two story warehouse with second level platform.”

A3. Mislabeled. Should be Multi Purpose Room 2

Q4. For our energy modelling we would like to know the expected usage of the building. What will be the operating hours, 8:00 to 4:30, how many people will be in the building – especially the assembly/meeting rooms?

A4. Usage will be 16 hours/day including Saturdays and Sundays. Assume nominal use for # of chairs.

Q5. Will geothermal be expected in Springhill, they already have some in Fenbrook

A5. Geothermal is not required.

Q6. "Electrical, Telecom and LAN rooms", data sheet indicates requirements for "goose neck, spray wand and a floor drains"? Please clarify as this appears to be a typo.

A6. This is a typo.

Q7. "Warehouse", data sheet indicates a "deep" S.S. sink. Please clarify the depth of sink required.

A7. Standard laundry sink is required.

Q8. "Secondary stair and Main vestibule", data sheets indicate "'other" in heat producing equipment. What is meant by this statement?

A8. Designer to provide best option.

Q9. 4. The Terms of Reference documents, in paragraph 5.5.12.1 .e, indicate that lighting is to be at 120 volt. Is it acceptable to use 347 volt for the lighting to reduce the Transformer capacity (and the associated heat rejection), panelboard sizes, etc?

A9. No.

Q10. Room data sheet, "meeting room large. Indicates domestic hot and cold water service required but does not indicate type of fixture, nor are they indicated on the drawings?

A10. Stub in drain and supply to wall between the Mechanical Room and Meeting Room Large.

Q11. Room data sheet, "warehouse" indicates "sink, hose bib and floor drains, but none are indicated on the drawings. Do we assume a location for the aforementioned?

A11. This is to be part of the design. Designer to locate where practical.