

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet Const.Svc,14 Bed Live Unit,Nova Ins	
Solicitation No. - N° de l'invitation EC016-133509/A	Amendment No. - N° modif. 007
Client Reference No. - N° de référence du client R.043957.001	Date 2013-04-25
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3237	
File No. - N° de dossier PWB-2-35164 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-04-30	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Cette modification de l'invitation numéro sept (7) est soumise et comprend la modification numéro 7 suivante.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des documents de contrat.

Toutes autres conditions ne changent pas.

Addenda numéro 7

1. DEVIS

.1 Reference Specification Section 01 50 00:

.1 Delete Clause 1.6.2.3, 'posts to be sunk minimum..' and replace with the following:

“.3 Posts to be driven minimum600mm into the ground. Concrete footings are not permitted”

.2 Reference Specification Section 07 21 13:

.1 Add paragraph 2.1.1 to read as follows and renumber accordingly:

“.1 Expanded Polystyrene Insulation

.1 Expanded to CAN/ULC-S701

.2 Type 3

.3 Required RSI value 1.76.

.4 Insulation value thickness per inch based on value listed in the latest edition of NRC - Evaluation listing.”

.2 Revise paragraph 2.2.1 to read as follows:

“.1 Extruded Polystyrene Insulation / Expanded Polystyrene Insulation:”

.3 Revise paragraph 2.2.1.1 to read as follows:

“.1 Extruded / Expanded to CAN/ULC-S701”

.4 Revise paragraph 2.4.1 to read as follows:

“.1 Extruded Polystyrene Insulation / Expanded Polystyrene Insulation:”

.5 Add paragraph 2.4.1.2 to read as follows and renumber accordingly:

“.2 Expanded to: CAN/ULC-S701, Type 3”

2. **DESSINS**

.1 **Reference Drawing A-004 - Wall and Finish Schedule:**

- .1 1/004 - Delete reference to 'SC-SEALED CONCRETE (EPOXY FLOORING)' in the Legend section of the Finishes Schedule and replace with 'C1-EXPOSED CONCRETE'
- .2 1/004 - Delete all references to 'SC-1' in the Schedule items and replace with 'C1'

.2 **Reference Drawing A-103 - Level 1 Reflected Ceiling Plan:**

- .1 1/103 - In Rooms 114 (Mechanical Room), 116 (Electrical Room) and 115 (Lan Room), the ceilings are to receive spray-on fire proofing only, as noted on drawings. These 3 rooms DO NOT receive the rock wool foil faced insulation as noted on Drawing A-001, Floor Type Legend. (Type F2).

3. **QUESTIONS ET RÉPONSES**

Q1: Is there any asphalt work required?

R1: Asphalt is mentioned in section 32 98 00 Reinstatement (patching if they have to cut into the existing asphalt).

Q2: Reference Addendum # 4 Section 3. Drawings .01 and Section 07 46 13-2.2 - Please advise what soffit material to be used as section 07 46 13 2.1 was deleted as of Addendum # 4.

Reference Addendum # 4 Section 3. Drawings .4 and Section 07 61 00 2.6 - Please advise what soffit material to use as the products specified are Metal and the addendum #4 states to use aluminum soffit.

R2: Our addendum #4 struck out section 2.1 (Vertical metal cladding) and directed the bidders to use section 2.2 for the soffit.

Addendum #4 does not say that the soffit is to be Aluminum, neither does 07 46 13 section 2.2. The material is to be perforated steel.

Solicitation No. - N° de l'invitation

EC016-133509/A

Client Ref. No. - N° de réf. du client

R.043957.001

Amd. No. - N° de la modif.

007

File No. - N° du dossier

PWB-2-35164

Buyer ID - Id de l'acheteur

pwb020

CCC No./N° CCC - FMS No/ N° VME

Q3: Refer to Division 10, Part 2 Products, 2.1 Room Signage

Supply and install room signage. "Design provided by departmental representative".

Can you supply this sign layout for pricing purposes?

R3: Signage is shown on dwg A-005. See Room Identifier 5/A-005.

4. **DOCUMENT DE L'APPEL D'OFFRES**

Conditions Supplémentaires - **SUPPRIMEZ** CS01 Ajustement du Prix du Bitume