

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Public Works Government Services Canada- Bid**  
**Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 421**  
**Saint John**  
**New Brunswick**  
**E2L 2B9**

## **SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### **Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Public Works Government Services Canada- Bid**  
**Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 421**  
**Saint John**  
**New Bruns**  
**E2L 2B9**

<b>Title - Sujet</b> General Purpose Bldg-N.B./N.S.	
<b>Solicitation No. - N° de l'invitation</b> EC016-123090/A	<b>Amendment No. - N° modif.</b> 010
<b>Client Reference No. - N° de référence du client</b> R.043958.001	<b>Date</b> 2012-05-02
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWB-007-3063	
<b>File No. - N° de dossier</b> PWB-1-34209 (007)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2012-05-17</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Atlantic Daylight Saving Time ADT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Ellis-Herring , Alison PWB	<b>Buyer Id - Id de l'acheteur</b> pwb007
<b>Telephone No. - N° de téléphone</b> (506) 636-3908 ( )	<b>FAX No. - N° de FAX</b> (506) 636-4376
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

This Solicitation Amendment Number Ten (10) is raised to include the following addendum.

The following Addendum to the tender documents is effective immediately. This Addendum shall form part of the contract documents.

**All other terms and conditions remain the same.**

## **Addendum No. 10**

### **1. EXTENSION**

Notice is hereby given that the time for the reception of tenders previously due May 10, 2012 is hereby extended to 14:00, May 17, 2012.

All enquiries must be submitted in writing to the Contracting Authority no later than May 7, 2012. Enquiries received after that time may not result in an answer being provided.

### **2. QUESTIONS AND ANSWERS**

Q1. Please advise if you have any specifications for Lockers - Toilet Accessories etc  
Lockers - Size required - Single Tier - Double Tier Are bases and slope tops required ?

A1. All details are included in Terms of Reference section 5.3.2.22

Q2. Washroom Accessories - Standard accessories required only. Grabbers? Stainless Steel accessories

A2. See Terms of Reference Section 5.3.2.21 also see notes from previous set of questions. Fixtures that are not BF can match qualities listed. Determining the Grab bar requirements and other elements of accessibility would be considered to be part of the design process when determining how the building meets CSCA Barrier free/Accessible design Standards.

---

Q3. Folding shower Seats - Are we to assume folding shower seats in each washroom or just the showers?

A3. See Terms of Reference section 5.3.2.21. Shower seat applies to showers only.

Q4. Mirrors - please advise size required

A4. Size determine as part of design of room. See notes in Terms of Reference section 5.3.2.21.iv

Q5. Can you please provide room data sheets for the mechanical rooms?

A5. As the final design of these rooms is based on the final building design RDS was not developed. CSC will review and may provide but generally the warehouse qualities could be applied.

Q6. Is there a requirement to provide a temporary fence around the contractor parking & laydown areas for each site or is this at the discretion of the design-builder?

A6. All contractor areas must be fenced, (see Terms of Reference for details on temporary fences) some parking may be located with regular parking at some sites, these would not need to be fenced. Site drawings should indicate lay down areas and parking.

Q7. Room data sheet 'Warehouse' indicates under the floor section 'concrete/sealed'. Does this apply to the mezzanine as well as the ground floor area?

A7. Room data sheets indicate that the warehouse is 325m2 with 120m2 on second level, this means the mezzanine. RDS applies to both levels.