

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Travaux publics et Services gouvernementaux
Canada
Place Bonaventure, portail Sud-Est
800, rue de La Gauchetière Ouest
7 ième étage
Montréal
Québec
H5A 1L6
FAX pour soumissions: (514) 496-3822

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Travaux publics et Services gouvernementaux Canada
Place Bonaventure, portail Sud-Est
800, rue de La Gauchetière Ouest
7 ième étage
Montréal
Québec
H5A 1L6

Title - Sujet Accès Internet	
Solicitation No. - N° de l'invitation W8484-12P2F0/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client W8484-12P2F0	Date 2012-03-12
GETS Reference No. - N° de référence de SEAG PW-\$MTA-850-11975	
File No. - N° de dossier MTA-1-34475 (850)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-03-19	Time Zone Fuseau horaire Heure Avancée de l'Est HAE
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Jutras, Jessie	Buyer Id - Id de l'acheteur mta850
Telephone No. - N° de téléphone (514) 496-3871 ()	FAX No. - N° de FAX (514) 496-3822
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Here is a list of questions received and the answers to these questions.

Q1. SOR 3.1.10, Please clarify the requirements for this link. For example is it to be used to allow DND access to their systems for management, video and picture uploads, to provide internet access for 1420 Ste Catherine etc.

A1. We need one 100Mbps link between the 1420 Sainte-Catherine west and the data center to synchronize our NAS. This NAS contain 70Tb of data which need to be synchronize with is backup clone at our office(Obviously incremental but we require unlimited bandwidth nonetheless).

The other link is the internet access of the 1420 Sainte-Catherine west office. We require a speed of at least 10Mbps and at least 7tb of monthly bandwidth(excluding transfers from the 100Mbps link which should be unlimited).

Q2. SOR 3.1.11, Please confirm a vascular scan system can be used instead of a fingerprint system. Vascular can provide a much higher level of security.

A2. Vascular scan system would do too.

Q3. SOR 3.1.11, Please clarify the requirements for access to a second data centre. Is the intent that this second centre is a disaster recovery (DR) site? If so, what are the requirements for the DR site in terms of systems (hot / cold backup systems) rack space to allow DND to bring in new equipment etc? Does the second data centre also need to be within 30KM of 1420 Ste Catherine?

A3. Yes both sites have to be within 30km if the 1420 Sainte-Catherine west

Q4. Please provide a detailed architecture / design diagram of the DND infrastructure showing elements such as web servers, database servers, networking equipment etc.

A4. We cannot provide this at this level. We require a full 42U cabinet independently of its content. If you require this information to assess the used amps, we almost use our 2 20amps circuits at full capacity.

Q5. SOR 3.2.2, Please provide details on what is included in technical support services.

A5. Support such as server racking, server reboot, emergency moving, networking(ie: rooting, bandwidth and dns issue). We will not need any support concerning os installation, applications running on our servers, etc.

All other terms and conditions remain the same.