

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet Const.Svc,14 Bed Live Unit,Nova Ins	
Solicitation No. - N° de l'invitation EC016-133509/A	Amendment No. - N° modif. 008
Client Reference No. - N° de référence du client R.043957.001	Date 2013-04-25
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3237	
File No. - N° de dossier PWB-2-35164 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-04-30	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Cette modification de l'invitation numéro huit (8) est soumise et comprend la modification numéro 8 suivante.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des documents de contrat.

Toutes autres conditions ne changent pas.

Addenda numéro 8

1. DEVIS

.1 Reference Specification Section 07 46 13, 'Preformed Metal Cladding / Siding Panels'

- .1 Sub-section 2.1.7 - Add the following to 'Acceptable Materials'.
 - “.3 Manufacturer: Roll Form Group Model: S-12-R-12-R
 - .4 Manufacturer: Agway Metals, Model: HF-12F
 - .5 Manufacturer: Ideal Roofing, Model: Urban Accent Panel”

.2 Reference Specification Section 07 61 00, Standing Seam Metal Roofing System

- .1 Sub-section 2.2.7 Add the following to 'Acceptable Materials':
 - “.3 Manufacturer: Roll Form Group, Model: C-7 Snap-on Standing Seam”
- .2 Sub-section 2.2.5.1 Revise wording to read:
 - “Prefinished with factory-applied Silicone Modified Polyester coating.”
- .3 Sub-section 2.2.5.2: Delete this sub-section.
- .4 Sub-section 2.2.5.3 Revise wording to read:
 - “Colour selected by Departmental Representative from manufacturer's standard stock range. Ensure the entire requirements for the project are supplied under one lot to eliminate any colour differential.”

.3 Reference Specification Section 07 21 13:

- .1 Sub-section 2.1.1.1.5 Revise wording to read: “Complete with a factory installed 6mm thick concrete facing.”

.4 Reference Specification Section 10 20 00:

- .1 Sub-section 2.4 Security Key Cabinet Delete this sub-section.

.5 Reference Section 23 21 14:

- .1 Paragraph 2.7: Delete line “.4 Heating Elements: 1 @6000W, 208/1.”
- .2 Add the following section:

2.8 Glycol

- .1 Pre-Mixed inhibited propylene glycol 40% by weight as indicated.
- .2 Application: Glycol heating/cooling distribution systems. Refer to section 23 81 41 for Earth Ground loop collector system glycol.

.6 Reference Section 23 25 00 HVAC Water Treatment:

- .1 Delete paragraphs 2.4, 2.6, & 2.7.

2. DESSINS**.1 Reference drawing E000, Fixture Schedule**

- .1 Add the following manufacturers as acceptable lighting fixture alternates:
Lithonia, Visioneering.

.2 Reference drawing E001, Site Plan Electrical

- .1 Clarification: Spare u/g conduits to stop at accessible attic space in existing building.

.3 Reference drawing E506, Power Riser Diagram

- .1 Clarification: Existing 1200amp Panel in main electrical is Westinghouse.

.4 Reference Drawing C-101 Existing Conditions Plan:

- .1 Amend Drawing C-101 to add maximum permitted limit of temporary fence and Relocation of existing shed in accordance with attached sketch C-101r - Attached as ATT 3.