

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet Reshingle Roofs, Nova Institution	
Solicitation No. - N° de l'invitation EC016-122834/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client R.043945.001	Date 2012-03-07
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3050	
File No. - N° de dossier PWB-1-34200 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-03-13	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Tender Amendment Number 6 is raised to include the following **Addendum No. 6.**

The following Addendum to the tender documents is effective immediately. This Addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 6

QUESTIONS AND ANSWERS

Q1: Can a Waste Container for the old shingles be placed on site and removed when full? Say once every week or every two weeks. Or do we have to remove it daily with a dump truck or trailer ?

A1: Waste containers has to be removed daily.

Q2: Staging:- Can it be left up till roof completed? Does it need to be horded off at bottom say up 8 ft with plywood to keep people off?

A2: The staging can be left till the roof is completed as long as its horded off at bottom with plywood (height of plywood 8 ft min) to keep inmates off staging.

Q3: Washrooms: Is there on being provided for workers by owners ? or do we supply Portable Toilet. If so can it be left near work zone if locked to pole and door locked when workers not on site?

A3: Portable toilet is allowed on site as long its locked at all times.

Q4: Can all material for the complete project be delivered at once and stored beside each unit if tarped?

A4: Material cannot be stored within fence area. A space outside the fence/compound will be determine once the contractor is on site.

Q5: Who supplies and pays for commissionaire? Owner or General Contractor

A5: Nova Institution.

Q6: Eaves trough - How many downspouts per each unit?

A6: 2 for large roofs, 1 for small roof.

Q7: Step Flashing – Can existing step flashing be reused or does the siding have to be removed and new step flashing added?

A7: Re-use existing flashing.

Q8: Can we leave construction staging in place during reroofing and are there restrictions such as closing of the base when not in use?

A8: Waste containers has to be removed daily.

Q9: Can we leave a locked construction trailer on site during construction?

A9: No it cannot be left within the fence/compound, Construction trailer can be left outside of compound - to be determine once contractor is on site.

Q10: Are washroom facilities provided and if not can we place a portable toilet on site during construction?

A10: Portable toilet is allowed on site as long its locked at all times

Q11: Can we place an open dumpster on site during construction?

A11: Waste containers has to be removed daily

Q12: I request clarification of sections 1.2 and 1.3 (warranty) contained within document "Division 07 - Thermal and Moisture Protection". Are these sections suggesting that the manufacturer guarantee to cover labour to replace defective shingles and if so what is the period?

A12: Article 1.2, we are simply extending the warranty period from 12 to 24 months. The contractor is responsible for that aspect of the warranty. Article 1.3, means that if there is a defect with the material within the said period, the manufacturer shall be responsible for material and

labour cost. The manufacturer will have to submit a certificate outlining the conditions of the warranty for their product.

Q13: Are the buildings to be reshingled one-storey or two-storey?

A13: Building R1, R2, R3 & R4 are two storeys and the PFV is one storey.