

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet Const.Svcs, Westmorland Inst, N.B.	
Solicitation No. - N° de l'invitation EC016-132714/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client R.043939.001	Date 2013-01-22
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3192	
File No. - N° de dossier PWB-2-35125 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-02-06	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Cette modification de l'invitation numéro cinq (5) est soumise et comprend la modification numéro 5 suivante.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des documents de contrat.

Toutes autres conditions ne changent pas.

Addenda numéro 5.

1. **DRAWINGS**

1. **Drawing M100 (Plumbing Sanitary & Venting Plans)**

1. **Detail 1/M100 (Mezzanine Plan - Sanitary and Vent Piping):**

- .1 DHWR Pump CP-5 in Mechanical Room Mech 201 shall be re-labeled CP-4.

2. **Detail 2/M100 (Main Floor Plan - Sanitary and Vent Piping):**

- .1 Sanitary piping from water closet in staff WC 115 shall be 75 from water closet to sanitary main in washroom area corridor.
.2 Sanitary piping from 38 stub out in Lunch Room 120 shall be 50 to 3rd lavatory take off. Remainder of sizing as shown.
.3 Fixture P1 in Room 119 shall be serviced from a 75 sanitary drain.

2. **Drawing M102 (Plumbing Details):**

1. **Detail 6/M01 (Natural Gas DHW Heater Detail):**

- .1 DHW Recirc. Pump (CP-5) shall be re-labeled (CP-4).
.2 Acceptable manufacturer: Zurn.

2. **Detail 2/M100 (Interception Detail):**

- .1 Oil interceptor shall have a flow rate capacity of 25gpm. Interceptor and holding tank shall be from same manufacturer. Acceptable manufacturers: Zurn, Watts.

3. **Drawing M300 (Ventilation Plans and Drawing M301 Ventilation Sections):**

1. **Intake and Exhaust Louvers:** Acceptable manufacturers: Ventex.
4. **Drawing M302 (Ventilation Controls & Schedules):**
 1. **Detail 2/M300 (HRV-2 Control):**
 - .1 Power to HRV-2 shall read 208/3 by electrical and power to heating coil HC-1 shall read 600V/3 by electrical.
 2. **Detail 3/M300 (HRV-3 Control):**
 - .1 Power to HRV-3 shall read 600V/3 by electrical.
 3. **Detail 9/M300 (Welding Exhaust Arm):** Acceptable manufacturers: Nederman, AQC-Maxair.
 4. **Exhaust Fan Schedule:** Acceptable manufacturers: Loren Cook, AQC-Maxair.
 5. **Electric Duct Heating Coil Schedule:** Acceptable manufacturer: Thermolec.
2. **SPECIFICATIONS**
 1. **Specification Section 22 13 18: DRAINAGE WASTE AND VENT PIPING - PLASTIC**
 1. **Section 22 13 18 - 2.1.3:** - Delete reference to CAN/CSA - B182.1 and replace with BDS to B182.1 not accepted.
 2. **Specification Section 22 42 01: PLUMBING SPECIALTIES AND ACCESSORIES**
 1. **Section 22 42 01 - 2.6:** - Acceptable manufacturer: Wilkins.
 2. **Section 22 42 01 - 2.7:** - Acceptable manufacturer: Zurn.
 3. **Section 22 42 01 - 2.8:** - Acceptable manufacturer: Wilkins.
 3. **Specification Section 22 52 04: IN-FLOOR HEATING PIPING**
 1. **Section 22 52 04 - 2.1.2:** - Acceptable manufacturer: Vanguard.

4. **Specification Section 23 33 14: DAMPERS**

1. **Section 23 33 14 - 2.4.5:** - Acceptable manufacturer: Alumavent.

5. **Specification Section 23 34 00: COMMERCIAL FANS**

1. **Section 23 34 00 - 2.2.3:** - Acceptable manufacturer: Loren Cook.

6. **Specification Section 25 01 01: DIRECT DIGITAL CONTROL SYSTEM**

1. **Section 25 01 01 - 1.1.1:** - Add "The existing control system at this institution is a T.A.C. LON based communication control system. The new Control System shall be a T.A.C. based control system with LON based communication and into existing control system in Building H-45. Replace all reference to Alartton Control System/BACNet with T.A.C. LON.