

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet 50 Bed Living Unit, Westmorland Ins	
Solicitation No. - N° de l'invitation EC016-130878/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client R.043929.001	Date 2012-08-29
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3101	
File No. - N° de dossier PWB-2-35024 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-09-13	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Cette modification de l'invitation numéro 4 est soumise et comprend la modification numéro 4 suivante.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des documents de contrat.

Toutes autres conditions ne changent pas.

Modification numéro 4

DESSINS

1. Reference Drawing E-002:

- 1 Add one 27mm Rigid PVC conduit for PPA system to section B-B from New 50 Bed Living Unit Building to Building F-58.

2. Reference Drawing E-300:

- 1 Add one L5-15R twistlock receptacle in Lan. Room 004 mounted to suit Senstar PPA receiver. Wire receptacle to panel EM circuit #57.

3. Reference Drawing E-301:

- 1 Add one L5-15R twistlock receptacle in Janitors Closet 121 mounted to suit Senstar PPA receiver. Wire receptacle to panel EM circuit #59.

4. Reference Drawing E-302:

- 1 Add one L5-15R twistlock receptacle in Mech/Elect N210 mounted to suit Senstar PPA receiver. Wire receptacle to panel EM circuit #61

5. Reference Drawing E-400:

- 1 Provide and install PPA (Personal Protection Alarm) receiver in Lan. Room 004 c/w 2C18 AWG twisted pair + #12B in 21mm(3/4)C back to Security Cabinet in Lan Room 004. PPA receivers shall be purchased from Senstar-Stellar Ottawa, Ontario.

6. Reference Drawing E-401:

- 1 Add one supervised valve and one flow switch to second range in Kitchen E114
- 2 Provide and install PPA (Personal Protection Alarm) receiver in Janitors Closet 121 c/w 2C18 AWG twisted pair + #12B in 21mm(3/4)C back to Security Cabinet in Lan Room 004. PPA receivers shall be purchased from Senstar-Stellar Ottawa, Ontario.

7. Reference Drawing E-402:

- Add two exterior PTZ (Pan/Tilt/Zoom) cameras to roof above on outer corners of building Grid Lines 8/A 18/A. Refer to 4/E505 for wiring.
- 2 Provide and install PPA (Personal Protection Alarm) receiver in Mech/Elect N210 c/w 2C18 AWG twisted pair + #12B in 21mm(3/4)C back to Security Cabinet in Lan Room 004. PPA receivers shall be purchased from Senstar-Stellar Ottawa, Ontario.

8. Reference Drawing E-505:

- 1 Supply and install 25pr security cable + #12B in 27mmC from Security Electronics Equipment Cabinet to Existing Senstar equipment in building F-58. Provide and install all necessary hardware, receivers, programing, etc. for existing Senstar system in building F-58 to be expanded for new equipment.

9. Reference Drawing E-507:

- 1 Revise incoming secondary feeders from 8#600 KCMIL RW90 to 8#750 KCMIL RW90.

10. Reference Drawing E-601:

- 1 Add three 15A/1P breakers to panel EM circuits 57,59 and 61. Label as PPA Receives.

11. Reference Drawing C-103

- 1 Drawing C-103 Grading Plan is reposted as ATT 4 (EDD Ang.).

Solicitation No. - N° de l'invitation

EC016-130878/A

Client Ref. No. - N° de réf. du client

R.043929.001

Amd. No. - N° de la modif.

004

File No. - N° du dossier

PWB-2-35024

Buyer ID - Id de l'acheteur

pwb020

CCC No./N° CCC - FMS No/ N° VME