

The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project, to the extent referenced and shall become a part thereof. No considerations will be allowed for extras due to the Contractor, or to any Subcontractors or Supplier, not being familiar with this Addendum.

1 BIDDER'S QUESTIONS

- .1 Can the mineral insulated feeder cables noted on drawing E04 notes 8 and 9 be replaced with standard Tech 90 conductor cable?

Answer:

This question has been addressed in Addendum No. 2

- .2 There was talk at the site visit that training of contractor personnel (approximately 2 days) may be permitted for airside work in lieu of the commissionaire escort as noted in Addendum no. 1. Please provide clarity as to what is acceptable?

Answer:

To escort airside an individual requires a Certificate of Proficiency in Radio from Communications Canada and a site specific AVOP. The contracting of a Commissionaire for escort is the preferred method as they will already have airside experience. Refer to Addendum No. 1.

END OF ADDENDUM NO. 3