

Solicitation No. - N° de l'invitation

EJ196-130852/A

Amd. No. - N° de la modif.

002

Buyer ID - Id de l'acheteur

fk286

Client Ref. No. - N° de réf. du client

R.057064.002

File No. - N° du dossier

fk286EJ196-130852

CCC No./N° CCC - FMS No/ N° VME

This amendment is issued to answer a Bidder's question.

No other changes apply.

Q: Do you have a preferred vendor for the Hypertect controls that are within the scope of work?
I suspect we will need to carry a vendor with the software to interface/update this controls platform.

A: There is no preferred contractor for this inventory item. The "Hypertect" Chilled Water Controller makes use of a Distech I/O (Input/Output) BACNET open protocol (non-proprietary) controller which was designed by Hypertect Inc. and installed cooperatively by XL-Air Energy Services Inc/LAR-MEX. The successful contractor will be responsible for making whatever arrangements required for maintenance of this system on their own.