

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet Const.Svcs, Westmorland Inst, N.B.	
Solicitation No. - N° de l'invitation EC016-132714/A	Amendment No. - N° modif. 011
Client Reference No. - N° de référence du client R.043939.001	Date 2013-02-01
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3192	
File No. - N° de dossier PWB-2-35125 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-02-06	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Tender Amendment No. Eleven (11) is raised to include the following Addendum No. Eleven (11).

The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 11.

1. QUESTIONS AND ANSWERS

<u>ITEM</u>	<u>REFERENCE</u>		<u>DESCRIPTION</u>
1.	Drawing E100, note 1	Q:	Drawing E100, note 1 - Is this fiber optic cable existing and long enough to reach building F-56 and is the other end already terminated?
		A:	This fiber optic cable is existing and already terminated.
2.	Drawing E100, notes 6/7	Q:	Drawing E100, notes 6/7 - Is this the same fiber optic cable as is indicated on riser diagram 2/E100 or are there 2 62.5uM OM1 fiber optic cables?
		A:	Please refer to previous addendums referencing electrical items.
3.	Drawing E100	Q:	Drawing E100, riser detail 2/E100 and addendum #4 item 2.5 - existing fiber optic cable is terminated via ST. Per the riser diagram it would appear all is terminated ST. Can you please verify where LC terminations would be required?
		A:	Please provide required number of ST and LC terminations.

-
4. **Spec Section 27 15 05, item 3.1.1.2**
- Q: Specification Section 27 15 05 item 3.1.1.2 - can you please clarify the total quantity of fiber optic patch cords required. My interpretation is as follows, can you please confirm.
- a. 4x2 (2 LAN rooms F56 and F114). Total of 8 LC to ST duplex patch cords.
- b. 6 ST-ST duplex patch cords per riser 2/E100.
- A: Please refer to previous addendums referencing electrical items.
5. **Spec Section 27 15 04, item 2.1**
- Q: Specification section 27 15 04 item 2.1 - this item makes reference to a voice backbone cable, however this is not requested specifically in specifications or on any drawings. Can you please provide any clarifications if voice backbone is required and if so, what are the requirements for this item? i.e. point of origin, reference product, riser detail, etc.
- A: Please refer to previous addendums referencing electrical items where all communications to building is handled through fiber optic cables.
6. **Drawing E100**
- Q: In reference to drawing E100, detail 2/E100 - as well as addendum #4 items 1.1 and 2.1.3, we are just looking to confirm which part number is required for this item, as information appears to contradict.
- A: Please refer to previous addendums referencing electrical items for correct part numbers.
7. **Drawing E100, note 1**
- Q: In reference to drawing E100, note #1 - we are to terminate 24 strands can you please confirm that we are required to provide adapter strips as required to terminate fiber or fully populated wall mount enclosure to accommodate 48 strands.
- A: Please provide wall mounted enclosure to terminate 48 strands.

8. **Drawing E400, note 4**
- Q: In drawing E400, note 4 - specifications to not clearly identify if stainless steel faceplates are required for voice/data outlets. Can you please clarify if we are to provide stainless steel faceplates or plastic?

A: Please provide stainless steel faceplates.

2. **DRAWINGS**

1. **Drawing M202 (Heating Details & Schedules)**

1. **Detail 4/M200:**

.1 Delete by-pass filter around CP2 & CP3. Side stream filter with S. S. housing shall remain.

2. **Topographic Drawing**

1. Attached as ATT 4 (DSP Eng.) is the revised topo plan with the proper scaling 1:250. It's the contractor's responsibility to plot the drawing to the proper page size (B1) in order to have the 1:250 scale.

3. **SPECIFICATIONS**

1. **Specification Section 22 05 00: MECHANICAL GENERAL REQUIREMENTS**

1. **Section 22 05 00 - 11.7:** - Delete all references to fire stopping by mechanical contractor. Fire stopping shall be by general contractor as per Section 01 73 00 - 1.3.12.

2. **Specification Section 22 42 01: PLUMBING SPECIALITES AND ACCESSORIES**

1. **Section 22 42 01 - 2.9.2:** - Acceptable manufacturer: Expanflex.

3. **Specification Section 22 52 01: STEEL PIPING VALVES AND FITTINGS - HYDRONIC SYSTEMS**

1. **Section 22 52 01 - 3.2.1:** - Acceptable manufacturer: T. Donovan & Son.

4. **Specification Section 22 52 04: IN-FLOOR HEATING PIPING**

1. **Section 22 52 04 - 2.1.2:** - Alternate manufacturer: Roth
2. **Section 22 52 04 - 2.2.1:** - Delete section in its entirety.
3. **Section 22 52 04 - 2.4.1:** - Section shall read "Manifolds as per header schedule on drawing M202 - Heating Details & Schedules.