

**Attachment No. 004**

**Question:**

The specifications include a requirement for a BAS system described in EMCS: GENERAL REQUIREMENTS Section 25 05 01. However, in Section 25 05 01 page one, it states as follows:

**1.3 ACCEPTABLE SYSTEM MANUFACTURERS PRODUCTS**

.1 The System Manufacturer shall be Delta Controls.

Would you please clarify if we are only allowed to use Delta Controls or if we can provide an alternative product for this project?

**Response:**

Delta Controls is only allowed to match with the institution's existing Delta Controls system.