

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving - PWGSC / Réception des soumissions -
TPSGC
11 Laurier St./11 rue Laurier
Place du Portage, Phase III
Core 0A1 / Noyau 0A1
Gatineau, Québec K1A 0S5

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Construction Services Division/Division des services de
construction
11 Laurier St./11 Rue Laurier
3C2, Place du Portage
Phase III
Gatineau, Québec K1A 0S5

Title - Sujet Investigative & Tech. Lab Fit-Up	
Solicitation No. - N° de l'invitation EH900-122450/A	Amendment No. - N° modif. 008
Client Reference No. - N° de référence du client R.047856.002	Date 2012-02-23
GETS Reference No. - N° de référence de SEAG PW-\$\$FG-343-58271	
File No. - N° de dossier fg343.EH900-122450	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-03-01	Time Zone Fuseau horaire Eastern Standard Time EST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Cook, Kristin	Buyer Id - Id de l'acheteur fg343
Telephone No. - N° de téléphone (819) 956-6122 ()	FAX No. - N° de FAX (819) 956-8335
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CRTC Les Terrasses de la Chaudière 1 Promenade du Portage Gatineau, Quebec J8X 4B1	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EH900-122450/A

Client Ref. No. - N° de réf. du client

R.047856.002

Amd. No. - N° de la modif.

008

File No. - N° du dossier

fg343EH900-122450

Buyer ID - Id de l'acheteur

fg343

CCC No./N° CCC - FMS No/ N° VME

ADDENDUM N° 4

CRTC Computer Investigative and Technical Lab Fit-up

PROJECT NO. R.047856.002

Page 1 of 1
Date: February 23, 2012

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

GENERAL

- 1 Roofing and rooftop equipment support
 - .1 Engage the services of a qualified roofing contractor to provide roof penetrations and sealing for all roof work outlined in mechanical and electrical documents, including dry cooler support, piping support and roof penetration enclosure.

SPECIFICATIONS

- 1 Section 23 65 10 Air Cooled Fluid Cooler
 - .1 Add the following to article 3.1.1:
Dry cooler supports to include roof support structure in accordance with seismic engineer's design.
- 2 Section 28 31 00 Fire Detection and Alarm
 - .1 Delete article 1.4.1.1 entirely.
 - .2 Add new article 1.4.1.1 as follows:
Engage the services of Secur Fire, the existing fire alarm maintenance provider, to complete the work of all fire detection and alarm sections, including all fire alarm verifications and fire alarm bypasses to suit fire alarm and fire protection work.

DRAWINGS

- 1 Refer to drawing M1 – Mechanical Legend, Drawing List & Details
 - .1 Revise note on drawing detail 2/M1 to read: "Roofing, flashing and insulation work by roofing contractor."

- .2 Revise note on drawing detail 6/M1 to read: "New structural support frame designed by seismic engineer."