

PWGSC Ontario	SPECIFICATION	Section
Region Project	Addendum 03	Page 1
Number R.052025.001		2012-09-28

The following Addendum forms part of the contract documents for the CSC Joyceville (Project number R.052025.001)

This Addendum Number 03 contains 1 written page.

MECHANICAL

Specification:

Section 23 73 11 - AIR HANDLING UNITS - PACKAGED

1. Item 2.8.1, revise to read:

2.8.1 Provide air handling unit with factory installed unit controller, end devices and sensors. Unit shall come complete with control panel (refer to sequence of operation and controls spec). It is incumbent upon the bidder to demonstrate compatibility of their product(s) with that of Johnson Controls, the existing equipment. Proof must be provided in the form of correspondence from Johnson Controls.

2. Item 2.9.1 to 2.9.2; delete.

Section 25 05 01 - EMCS: GENERAL REQUIREMENTS

1. Items 1.6.1 to 1.6.4; delete.

2. Item 1.6.1; revise to read:

1.6.1 Manufacturers listed are known manufacturers of equipment similar to the existing. It is incumbent upon the bidder to demonstrate compatibility of their product(s) with that of Johnson Controls, the existing equipment. Proof must be provided in the form of correspondence from Johnson Controls.

End of ADDENDUM Number 03