

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, 12th floor
800,rue Burrard, 12e étage
Vancouver
British Columbia
V6Z 2V8
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, 12th floor
800, rue Burrard, 12e étage
Vancouver
British C
V6Z 2V8

Title - Sujet New 50 Man Living Units - Ferndale	
Solicitation No. - N° de l'invitation EZ899-131401/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client	Date 2012-11-06
GETS Reference No. - N° de référence de SEAG PW-\$PWY-005-6794	
File No. - N° de dossier PWY-2-35164 (005)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-11-09	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Pillay, Sal (PWY)	Buyer Id - Id de l'acheteur pwy005
Telephone No. - N° de téléphone (604) 775-9386 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CSC - Ferndale Institution - Mission, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EZ899-131401/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

006

File No. - N° du dossier

PWY-2-35164

Buyer ID - Id de l'acheteur

pw005

CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

SPECIFICATIONS

.1 07 44 56 - Fiber Cement Panel System

Paragraph 2.1.1:

- (1) **Add:** new paragraph .4
.4 All products meeting this specification specifically the panel, thickness, size, appearance, concealed fastening etc., are acceptable.

DRAWINGS

.1 Drawing E002 - Electrical Single Line Diagram and Generator Room Layout.

- (2) **Revise:** Detail A – Electrical Single Line Diagram, 'TX-1' kVA rating to read 150kVA.

END OF ADDENDUM No 5

Bidding Questions and Answers

The following questions received from bidders are listed for general reference only. Answers provided by PWGSC are intended to direct the bidder to a specific part of the Bid documents area, to answer their questions, or an Addendum Item reference number will be noted to direct the Bidder where changes to the Bid documents are necessary to answer the questions.

- .1 Question: I apologize for taking so long to come to you with this request for alternate approval. We actually have two products that we'd like to propose as alternates for the Ferndale Institution project. Euro Panels' Eternit Eter-Color and Eter-Board HD are of similar composition, except Eter-Color comes in one 8mm thickness, is available in 8 through colours and has a brushed or textured surface. Please refer to: <http://www.engineeredassemblies.com/products/eternit-fibre-cement-panel.aspx> for more information on Eter-Color. Eter-Board HD, on the other hand, comes in 6 thicknesses and comes in a smooth, natural grey finish that can be painted any colour with the approved PPG Duracolor system. Please refer to Page 8 of the attached brochure for more information on Eter-Board HD. Eter-Color and by extension, Eter-Board HD, have been fire tested to CAN/ULC S135, which means both are approved for use on sprinklered, or non-sprinklered buildings of any height.

Answer: Products must meet the specification specifically panel size, thickness and appearance. See Addendum Item (1)

END OF Q & A
