

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
**Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada**
800 Burrard Street, 2nd floor
800,rue Burrard, 2e étage
Vancouver
British Columbia
V6Z 2V8
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, 12th floor
800, rue Burrard, 12e étage
Vancouver
British C
V6Z 2V8

Title - Sujet Sinclair Centre Revitalization Ph.1	
Solicitation No. - N° de l'invitation EZ899-132937/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client	Date 2013-02-25
GETS Reference No. - N° de référence de SEAG PW-\$PWY-020-6918	
File No. - N° de dossier PWY-2-35326 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-03-01	Time Zone Fuseau horaire Pacific Standard Time PST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ly, Ronny(PWY)	Buyer Id - Id de l'acheteur pwy020
Telephone No. - N° de téléphone (604) 666-0043 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: PWGSC - Sinclair Centre, Vancouver, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EZ899-132937/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

004

File No. - N° du dossier

PWY-2-35326

Buyer ID - Id de l'acheteur

pw020

CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande

Vous trouverez l'addenda n° 2 ci-joint.

Les autres conditions ne changent pas.

*The following changes in the Tender Documents are effective IMMEDIATELY.
This addendum will form part of the Contract Documents*

Amend / revise Standard Contract Documents as follows:

1.0 ARCHITECTURAL DRAWINGS

- 1.1 Refer to:** Architectural Sketches, all dated February 22, 2013
AD-09

End of Addendum #2

DEMOLITION LEGEND:

- 24

= REMOVE EX. FIRE EXTINGUISHER &
HAND IT OVER TO OWNER
- 25

= NOT USED
- 26

= NOT USED
- 27

= DEMOLISH EXISTING FLOORING AND
BASE
- 28

= DEMOLISH EXISTING SHEET FLOORING
AND COVE BASE
- 29

= NOT USED
- 30

= REMOVE EXISTING DISPLAY CASE
- 31

= DEMOLISH EXISTING MILLWORK OR
EQUIPMENT
- 32

= REMOVE EXISTING PLUMBING FIXTURES
& ASSOCIATED PLUMBING (REFER
MECHANICAL DRAWINGS)

<div>CHERNOFF THOMPSON ARCHITECTS Vancouver, B.C. Phone: 604.669.9460</div>	<div>DRAWING: DEMOLITIONS - PHASE 1 LOWER MALL (SE) & UPPER MALL(NE) FLOOR PLANS</div>	SCALE: 1:100	REV: 0
		DATE: 22 FEB '13	
		DRAWN: PW/TY	
		PROJECT NO: R.041365.001	AD-09

3.0 METHODOLOGY

The site review and sampling was completed by DST on November 5 and November 6, 2012.

Suspect hazardous building materials were visually identified, based on the surveyor's knowledge of the historic composition of building products. Visual identification of materials suspected to contain hazardous materials were supported by the analysis of representative samples.

Suspect ACM samples were analyzed for asbestos content at Asbestos Analytical Services Ltd. (AASL) following the National Institute for Occupational Safety and Health (NIOSH) Method 9002.

Suspect LBCs samples were tested for lead content using a Niton X-Ray Fluorescence (XRF) spectroscopy detector. The Niton XRF is designed to detect and quantify the amount of lead present in painted surfaces. Measurements were made following Niton XRF standard operating procedures for lead in surface coating measurements.

Suspected ozone-depleting substances (ODSs), elemental mercury, sources of polychlorinated biphenyls (PCBs), mould amplification, animal droppings and crystalline silica were visually identified based on appearance, age, and knowledge of historic applications/locations.

4.0 FINDINGS

4.1 Asbestos-Containing Materials (ACMs)

Forty eight (48) samples of suspect ACMs were collected and analyzed for asbestos content. Asbestos analytical reports are included in **Appendix I**. The sample descriptions and analytical results are summarized in **Table 1**, below. Drawings indicating sample point locations are presented in **Appendix II**.

Table 1: Analysis of Suspect ACMs Sinclair Center – 757 West Hastings Street, Vancouver, BC			
Sample I.D.	Sample Description	Sample Location	Asbestos Content & Type
SC-01	Blue Vinyl Sheet Flooring	Lower Mall / Food court corridor	None-Detected
SC-02	Red hard fire stop mastic around conduits	Lower Mall / Food court corridor	None-Detected
SC-03	Leveling compound near conduits	Lower Mall / Food court corridor	None-Detected
SC-04	Drywall Joint Compound	Lower Mall / Food court / "Fortune Wok"	None-Detected