

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services / Travaux
publics et services gouvernementaux
Kingston Procurement
Des Acquisitions Kingston
86 Clarence Street, 2nd floor
Kingston
Ontario
K7L 1X3
Bid Fax: (613) 545-8067

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services / Travaux
publics et services gouvernementaux
Kingston Procurement
Des Acquisitions Kingston
86 Clarence Street, 2nd floor
Kingston
Ontario
K7L 1X3

Title - Sujet MASS NOTIFICATION SYSTEM	
Solicitation No. - N° de l'invitation W0046-12Q101/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client W0046-2-Q2101	Date 2012-06-18
GETS Reference No. - N° de référence de SEAG PW-\$KIN-675-5859	
File No. - N° de dossier KIN-1-36458 (675)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-06-29	Time Zone Fuseau horaire Eastern Daylight Saving Time EDT
F.O.B. - F.A.B. Specified Herein - Précisé dans les présentes Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input checked="" type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Chan, Ricky	Buyer Id - Id de l'acheteur kin675
Telephone No. - N° de téléphone (613) 545-8738 ()	FAX No. - N° de FAX (613) 545-8067
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

The purpose of this amendment is to respond to questions related to this bid solicitation as detailed below:

Question No.	Reference Paragraph	Question	Response
1	4,3	States The MNS must cover all exterior areas south of Highway 2. Is it the intent of this sentence to provide minimal coverage in the area north of Highway 2?"	We only require coverage south of highway 2.
2	4,4	States: the MNS must be capable of interfacing with other MNS in the RMCC geographical vicinity". Please provide a list of all MNS that are installed in the vicinity. Please include the manufacturer name	Please see Question 1 of Amendment 1.
3	4,4	If there is additional equipment required for interfacing to the existing MNS is the equipment to be supplied by the successful bidder?	No.
4	4,4	If the answer to question # 3 is yes will it be mandatory for the existing system interface equipment supplier to provide connection drawings prior to bid? After the project is awarded?	No.
5	4,4	If the answer to question # 3 is no will the existing MNS manufacturer provide a list of their equipment requires for a proper interface?	No.
6	4,5	Feature 4.4.2 please expand on this requirement. Are auxiliary speakers spare" that can be used to replace a non-working speaker?"	Yes.
7	4,5	Feature 4.4.5 Please define Role based access".	Multi-level security and authority to operate the MNA based on user login credentials.
8	4,6	Please define System outages" to include the types of outages that will be expected to report."	UFC para 3-7.5 states the MNS shall provide self-test and diagnostic capabilities. Results of the routine diagnostics shall be logged with appropriate severity level to indicate status of MNS.
9	4,7	is it permissible to take advantage of the existing CAT 6 network?	Yes.
10	4,7	Is it the intention of this paragraph redundant forms of communication to be provided between the HPSA and the Central Control station?	Yes, redundant communications are required.
11	NA	UFC paragraph 3-5 requires redundant Central Control Stations. Will a redundant Control Station be required?	Redundant control station will be located at the RMC entrance guard house, building R79.
12	NA	Are there any restrictions to the type	They must meet all Ontario

		of poles that can be used for mounting the HPSA's?	engineering standards.
13		What is the required total coverage for voice and tone?	Please see Question 1 above.
14		Who provides power to the speaker arrays?	RMC electrical distribution.
15		What is the desired length of maintenance agreement?	As set out in the solicitation, the maintenance and support will be for one year with the option to extend by two additional one-year periods.
16		Is the RMC able to obtain the Radio Frequency licenses required from the Government?	Yes.
17		Is a Structural Engineer required to approve roof mount system for speaker arrays?	Yes, as set out in paragraph 4.9 of Annex A, "engineering work must be approved by appropriate engineers licenced in the Province of Ontario."
18		Is this Mass Notification a stand – a – lone system or will it be connected in any way to the existing fire alarm systems.	The Mass Notification System is a stand-alone system and will not be connected in any way to the existing fire alarm systems.
19		Are we able to use the existing Fiber Optic Network for our connections and is there additional room for New Switches that are to be provided by the Integrator.	Yes and yes.
20		To what extent is the RMC conduit system available for us to use and can you specify locations in Girouard and Sawyer Buildings.	RMC's conduit structure may be used provided there is room .
21		Can you confirm location of UPS and PC for the MNS System.	The primary location will be the Security control Centre in Girouard Building room GB231. The secondary location will be the entrance guard house, building R79.
22		Can you confirm preferred locations of UPS on Speaker Arrays.	Girouard Building.
23		Will we need to provide our own circuits for power on this system.	The Contractor must provide electrical wiring to the nearest power panel.
24		Is the intention of this RFP to only provide Speaker Arrays for the desired coverage.	Yes.
25		Are any form of "Permits" required for this project.	No.
26		Can you confirm "" or "" fiber in your infrastructure.	Both are available.

ALL OTHER TERMS AND CONDITIONS OF THE BID SOLICITATION REMAIN UNCHANGED