

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, 12th floor  
800, rue Burrard, 12e étage  
Vancouver  
British Columbia  
V6Z 2V8  
Bid Fax: (604) 775-9381

## **SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Pacific Region  
800 Burrard Street, 12th floor  
800, rue Burrard, 12e étage  
Vancouver  
British C  
V6Z 2V8

<b>Title - Sujet</b> Redev. of Floor B1 -Sinclair Centre	
<b>Solicitation No. - N° de l'invitation</b> EZ899-122573/A	<b>Amendment No. - N° modif.</b> 006
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2012-02-29
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-020-6584	
<b>File No. - N° de dossier</b> PWY-1-34396 (020)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-03-05</b>	<b>Time Zone</b> Fuseau horaire Pacific Standard Time PST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Ly, Ronny(PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy020
<b>Telephone No. - N° de téléphone</b> (604) 666-0043 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Services Canada - Sinclair Centre, Vancouver, B.C.	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation

EZ899-122573/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

006

File No. - N° du dossier

PWY-1-34396

Buyer ID - Id de l'acheteur

pw020

CCC No./N° CCC - FMS No/ N° VME

---

This Amendment 006 is raised to incorporate Addendum No. 4.

Please see the attached Addendum No. 4.

**ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.**

**ADDENDUM #4**

This Addendum is in addition to, and forms a part of the Contract. The cost, if any, of this revision(s) shall be included in the Contract price. All bidders shall acknowledge receipt and acceptance of this addendum by indicating Addendum number, date, and description, on the Tender Form provided. The revision(s) is as follows:

**REVISE THE ELECTRICAL SPECIFICATIONS AS FOLLOWS:**

1. Section 26 05 00, Common Work Results – Electrical:
  1. Change Clause 1.22.6 to read:  
“.6 Refer to Architectural Section 07 84 00 regarding Fire Stopping.”
2. Section 26 05 00, Common Work Results – Electrical:
  1. Change Clause 1.35.7 to read:  
“.7 Allow for.... one switch in each enclosed area (room) and one switch for the Lobby and Common areas.”
3. Section 26 52 01, Unit Equipment for Emergency Lighting:
  1. Change Clause 2.2.1 to read:  
“.1 Conduit: type EMT in accordance with.....”
4. Section 28 13 00, Access Control:
  1. Add Clause 1.2.2 as follows:  
“.2 System provided must obtain RIIS (Regional Internal Integrity and Security) approval prior to supply and installation of the system. Provide detailed layouts at time of Shop Drawings.”
5. Section 28 13 00, Access Control:
  1. Add Clause 2.3.8 as follows:  
“.8 Standard of acceptance of card access system shall be Keyscan Vantage Access Control System Version 8 1.1.12 by Keyscan.”

**REVISE THE ELECTRICAL DRAWINGS AS FOLLOWS:**

1. Drawing E4.0:  
Room B1-102:
  - .1 Provide and install five (5) Dual Technology glass break devices. Locate evenly spaced throughout the space as directed by the Departmental Representative.

Room B1-112:

- .1 Provide and install an Alert device to alert the staff that a citizen service door has been opened during normal working hours.

Room B1-125:

- .1 Provide and install one (1) Dual Technology glass break device. Locate in the space as directed by the Departmental Representative.

END OF ADDENDUM #4