

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet 50 Bed Living Unit, Westmorland Ins	
Solicitation No. - N° de l'invitation EC016-130878/A	Amendment No. - N° modif. 009
Client Reference No. - N° de référence du client R.043929.001	Date 2012-09-07
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3101	
File No. - N° de dossier PWB-2-35024 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-09-13	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Tender Amendment Number 9 is raised to include the following **Addendum No. 9**.

The following Addendum to the tender documents is effective immediately. This Addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 9

1. SPECIFICATIONS

1. Reference Specification Section 28 23 00

Amend Section 1.6.1 to read:

".1 The recording component of the IP CCTV system must be expanded as required to maintain CSC's requirement of a minimum of 168 hours of stored video for all cameras."
"

2. Reference Specification Section 28 23 00 - 'Video Surveillance'

Specification Section 28 23 00, Part 3.5, Add the following items:

".3 Provide on-site lectures and demonstration by fire alarm equipment manufacturer to train operational personnel in use and maintenance of Video Surveillance System.
.4 Allow for three (3) separate training sessions, one (1) hour for each."

3. Reference Specification Section 28 16 00 - 'Security Systems'

Specification Section 28 16 00, Part 1.1.3, Add the following items:

".4 Allow for three (3) separate training sessions, one (1) hour for each training session."

4. Reference Specification Section 27 51 16 - 'Public Address System'

Specification Section 27 51 16, Part 1.6.1, Add the following items:

".3 Allow for three (3) separate training sessions, one (1) hour for each training session."

5. Reference Specification Section 27 10 05 'Structured Cabling for Communications Systems'

Specification Section 27 10 05, Part 2.11, add the following:

"2 One-Port 100base-FX pluggable Ethernet Routing Switch- small form factor, to equal specification as above"

6. Reference Specification Section 26 05 29, 'Hangers and Supports for Electrical Systems'

Specification Section 26 05 29, Part 2, Add the following:

"2.2 Cable Trays

.1 Type 304 Stainless Steel Basket Tray c/w all necessary elbows, supports & installation hardware

.2 Size: 600mm wide by 60mm deep, with 50mm useable loading depth

.3 Straight Sections 3000mm long

.4 Tested Load Capacity 30kg with supports at 1500mm intervals."

7. Reference Specification Section 23 07 13 Thermal Insulation for Ducting

.1 Paragraph 3.4.1 "Warm Air Ducts" applies to all supply ductwork from the gas furnaces

.2 Paragraph 3.4.1 "Cold, dual temperature supply air ducts" applies to all other supply ductwork.

8. Reference Specification Section 23 07 15 Thermal Insulation for Piping

.1 Paragraph 3.6.7 Add "All Rainwater Piping, TAIC Code A-3, 25 mm"

2. DRAWINGS

1. Reference Drawing Number A-001 – Notes & Legends

Amend description of partition type P5 to read:

"45 minute fire separation (ULC 452)

Height to U/S of deck

- 64mm J-shaped floor, side & ceiling tracks secured to structural supports at 610mm OC

- 64mm C-H studs at 610mm OC

- 25.4mm Gypsum Liner Panels, 610mm wide inserted into 'H' portion of studs & long leg of 'J' runners

- 15.9mm Gypsum wallboard"

2. **Reference Drawing Numbers A-307 & A-308, 'Section Details'**

Details 1/307, 2/307, 3/307, 3/308 & 5/308: Delete note 'Coordinate with structural for size of wood lintel' on each detail.

We would like to provide a better resolution for this item, but there will not be enough time to co-ordinate this with structural. For the time being, bidders will have to price lintels as shown.