

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Public Works Government Services Canada- Bid**  
**Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 421**  
**Saint John**  
**New Brunswick**  
**E2L 2B9**

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Public Works Government Services Canada- Bid**  
**Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 421**  
**Saint John**  
**New Bruns**  
**E2L 2B9**

<b>Title - Sujet</b> General Purpose Bldg-N.B./N.S.	
<b>Solicitation No. - N° de l'invitation</b> EC016-123090/A	<b>Amendment No. - N° modif.</b> 016
<b>Client Reference No. - N° de référence du client</b> R.043958.001	<b>Date</b> 2012-05-17
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWB-007-3063	
<b>File No. - N° de dossier</b> PWB-1-34209 (007)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2012-05-29</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Atlantic Daylight Saving Time ADT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Ellis-Herring , Alison PWB	<b>Buyer Id - Id de l'acheteur</b> pwb007
<b>Telephone No. - N° de téléphone</b> (506) 636-3908 ( )	<b>FAX No. - N° de FAX</b> (506) 636-4376
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

This Solicitation Amendment Number Sixteen (16) is raised to include the following addendum.

The following Addendum to the tender documents is effective immediately. This Addendum shall form part of the contract documents.

**All other terms and conditions remain the same.**

## **Addendum No. 16**

### **1. TERMS OF REFERENCE**

**DELETE** Section 4.3.3.1:

The Design-Builder will appoint and pay for materials and systems testing identified in the Performance Specifications or the Design- Builders Proposal.

And **REPLACE WITH:**

4.3.3.1 The Design-Builder will appoint and pay for all materials and systems testing as identified in the Performance Specifications as well as any additional testing identified in the Design-Builders Proposal.

### **2. QUESTIONS AND ANSWERS**

Q1

Can you please confirm if the design-builder is responsible for all testing and inspections and borne all costs associated with this for compaction tests, concrete tests, etc. If we are responsible, is the frequency of the tests up to the design-builder?

A1

See Section 4.3.3 Quality Control and Section 5.1.18 Quality Assurance

Q2

What level of service records is required (Full digital coordinates of all underground)?

A2

See Section 4.3.13 Close-Out Submittals

Q3

Are there existing electrical single line for the correctional facilities. We are trying to see what distribution equipment is in the buildings they're indicating as potential "permanent electrical hook-up" on the site plan. Also, whether or not an emergency generator is present. The

---

documents indicate to provide a separate emergency power distribution to the new buildings, if there is one on site (couldn't find in the documents confirming whether or not there is a generator for the existing facilities). Please advise.

A3

-GO building at Atlantic Institution shall have only one electrical service, from the existing adjacent 2400V pole line.

-GI building in Springhill Institution shall have 2 separate electrical services, normal and essential, available at 600V in building #3 electrical room.

See attached single line diagrams for both sites (Attached as ATT 16).