

RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving - PWGSC / Réception des soumissions - TPSGC

11 LaurierSt./ 11, rue Laurier

Place du Portage, Phase III

Core 0A1 / Noyau 0A1

Gatineau

Québec

K1A 0S5

Bid Fax: (819) 997-9776

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

This document contains a security requirement.

Ce document comprend une exigence en matière de sécurité.

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Maintenance & Professional Consulting Services
Division (FK)

11 Laurier St.

3C2, Place du Portage, Phase

Gatineau

Québec

K1A 0S

■■■■■ ○○○○

Title - Sujet HVAC and Chiller Maint. CFS Leitrim	
Solicitation No. - N° de l'invitation EJ196-130852/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client R.057064.002	Date 2013-01-11
GETS Reference No. - N° de référence de SEAG PW-\$\$FK-286-61719	
File No. - N° de dossier fk286.EJ196-130852	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-01-25	Time Zone Fuseau horaire Eastern Standard Time EST
F.O.B. - F.A.B.	
Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lessard(FK Div), Gisele	Buyer Id - Id de l'acheteur fk286
Telephone No. - N° de téléphone (819) 956-2352 ()	FAX No. - N° de FAX (819) 956-3600
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	
PWGSC / TPSGC Phase III, Place du Portage 11 Laurier Street Gatineau, QC K1A 0S5 CANADA	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Solicitation amendment is raised to address the following:

1. At Request for Proposal (RFP), Part 1 - General Information, Article 1.2 (iii) **and** Part 7 - Resulting Contract Clauses, Article 7.1.1.:

DELETE Mandatory Response Time, in its entirety and **REPLACE WITH:**

(Updated) Mandatory Response Time

As per **Annex A**, Scope of Work 8M3-1588-10, EJ196-130852, SW 3.5 Emergency Calls, it is a mandatory requirement of the contract that:

.1 The Contractor must provide twenty-four (24) hour, seven (7) days a week emergency call back service for the duration of the contract.

.2 The Contractor must respond within thirty (30) minutes and be on site ready to work within **one (1) hour** of receiving the emergency call. All work for emergency service must be executed by a qualified service personnel named in the Contract and such work must proceed continuously until the system is returned to safe operating condition.

2. At Part 3 - Bid Preparation Instructions, Section II: Financial Bid:

DELETE Pricing Schedule 1 - Firm Price in its entirety and **REPLACE WITH:**

Pricing Schedule 1 - Firm Price

Firm all inclusive prices including all necessary tools, services and labour on heating, ventilation, air conditioning (HVAC) and related mechanical equipment and Chillers in accordance with the Scope of Work 8M3-1588-10, attached herein as Annex A.

Equipment Inventory

Export Development Canada (EDC) Building

Solicitation No. - N° de l'invitation

EJ196-130852/A

Amd. No. - N° de la modif.

001

Buyer ID - Id de l'acheteur

fk286

Client Ref. No. - N° de réf. du client

R.057064.002

File No. - N° du dossier

fk286EJ196-130852

CCC No./N° CCC - FMS No/ N° VME

No. of Units	Location Room No.	Make	Model	Serial Number	Details	Year 1	Year 2	Year 3	Year 4	Year 5
4	EDC Outside	Innovative HVAC Systems LLC	RPA240-LIES-6TFD-C	10040001 10040002 10040003 10040004	Thru-wall Heating/Cooling systems, R-407C 12.8 lbs, 460V, c/w Bard TEC40 Controller	\$	\$	\$	\$	\$
1	EDC Inside	Trane TruSense MG	RMWERP41 1D0	LT10M0662 7	Refrigerant Monitoring and Evacuation System	\$	\$	\$	\$	\$
1	EDC Inside	Nortec	NHTC+10	2,118,985	Electric Humidifier, 208V/1Ph, 3.7KW, 25 Amps	\$	\$	\$	\$	\$
1	EDC Outside	Motivair	MLCFE630	W04 AG 1025	Free Cooling Chiller, 460V, c/w pump(s) and Glycol Storage Tank	\$	\$	\$	\$	\$
1	EDC Outside	Heatcraft (Bohn)	BFH168	T12C113001	10 Fan Dry Cooler, 460V	\$	\$	\$	\$	\$
2	EDC Outside	Trane	RTAC 1705 Series R	U12C03056 (2A) U12D03425 (2B)	Air Cooled Helical Rotary Liquid Chiller 575/60/3, 170 Tons, R134a	\$	\$	\$	\$	\$
3	Pump House	Bell & Gossett	3G Series 1510	70629600B (2A) 706030100 (2B) 70629600A (2C)	CHP-2A, 2B, 2C Chiller Pumps, 25HP Inverter Duty Motors, 575/3/60, 1800 RPM, 400 GPM	\$	\$	\$	\$	\$
2	Pump House	Bell & Gossett	4BC Series 1510	70629500A (2A) 70629500B (2B)	DCP-2A, 2B Glycol Pumps, 10HP Inverter Duty Motors, 575/3/60, 1800 RPM, 400 GPM, c/w ABB Speed Drives	\$	\$	\$	\$	\$
1	Pump House	Axiom	SF100	12-10838-SF	Glycol Fill Station c/w By-pass Filter	\$	\$	\$	\$	\$
	Total for each year					\$	\$	\$	\$	\$
	Total for 5 years									

3. At Scope of Work, page 6 of 6:

DELETE SW5 Equipment Inventory in its entirety and REPLACE WITH:**SW 5 Equipment Inventory**

Building: Export Development Canada (EDC)

No. of Units	Location Room No.	Make	Model	Serial Number	Details
4	EDC Outside	Innovative HVAC Systems LLC	RPA240-L1ES-6TF D-C	10040001 10040002 10040003 10040004	Thru-wall Heating/Cooling systems, R-407C 12.8 lbs, 460V, c/w Bard TEC40 Controller
1	EDC Inside	Trane TruSense MG	RMWER P411D01 001AE	LT10M06 627	Refrigerant Monitoring and Evacuation System
1	EDC Inside	Nortec	NHTC+1 0	2118985	Electric Humidifier, 208V/1Ph, 3.7KW, 25Amps
1	EDC Outside	Motivair	MLCFE6 30	W04 AG 1025	Free Cooling Chiller, 460V, c/w pump(s) and Glycol Storage Tank
1	EDC Outside	Heatcraft (Bohn)	BFH168	T12C1130 01	10 Fan Dry Cooler, 460V
2	EDC Outside	Trane	RTAC 1705 Series R	U12C030 56 (2A) U12D034 25 (2B)	Air Cooled Helical Rotary Liquid Chiller 575/60/3, 170 Tons, R134a
3	Pump House	Bell & Gossett	3G Series 1510	70629600 B (2A) 70603010 0 (2B) 70629600 A (2C)	CHP-2A, 2B, 2C Chiller Pumps, 25HP Inverter Duty Motors, 575/3/60, 1800 RPM, 400 GPM
2	Pump House	Bell & Gossett	4BC Series 1510	70629500 A (2A) 70629500 B (2B)	DCP-2A, 2B Glycol Pumps, 10HP Inverter Duty Motors, 575/3/60, 1800 RPM, 400 GPM, c/w ABB Speed Drives
1	Pump House	Axiom	SF100	12-10838-SF	Glycol Fill Station c/w By-pass Filter

Other terms and conditions remain the same.