

**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS À:**

Regional Manager/Real Property  
Contracting/PWGSC  
Ontario Region, Tendering Office  
12th Floor, 4900 Yonge Street  
Toronto, Ontario  
M2N 6A6  
Ontario

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**  
Regional Manager/Real Property Contracting/PWGSC  
Ontario Region, Tendering Office  
12th Floor, 4900 Yonge Street  
Toronto, Ontario  
M2N 6A6  
Ontario

<b>Title - Sujet</b> Kingston (Bath), Segregation Yards		
<b>Solicitation No. - N° de l'invitation</b> EQ734-131870/A		<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b> R.058041.001		<b>Date</b> 2012-11-01
<b>GETS Reference No. - N° de référence de SEAG</b>		
<b>File No. - N° de dossier</b> PWL-2-35086 (003)		<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> at - à 02:00 PM on - le 2012-11-06		<b>Time Zone</b> Fuseau horaire Eastern Daylight Saving Time EDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>		
<b>Address Enquiries to: - Adresser toutes questions à:</b> Dhanna, Sheila		<b>Buyer Id - Id de l'acheteur</b> pwl003
<b>Telephone No. - N° de téléphone</b> (416) 512-5855 ( )		<b>FAX No. - N° de FAX</b> (416) 512-5862
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Correctional Service Canada Millhaven Institution Highway 33 Bath, ON K0H 1G0		

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> Raison sociale et adresse du fournisseur/de l'entrepreneur	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> (type or print) <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation

EQ734-131870/A

Client Ref. No. - N° de réf. du client

R.058041.001

Amd. No. - N° de la modif.

001

File No. - N° du dossier

PWL-2-35086

Buyer ID - Id de l'acheteur

pwl003

CCC No./N° CCC - FMS No./N° VME

---

## Questions and Answers:

Q:

Can you please clarify the requirements for the construction fence around the site and our lay down area. The drawings refer to 6 ft. standard construction fence, but the spec lists a 2x4 and plywood fence with barbed wire. This will make a significant difference in the cost of the fence.

A:

Refer to Addendum No.01., Section 01 56 00 - Temporary Barriers and Enclosures. 2x4 and plywood fencing is not required. No fencing is required for the lay down area.

Q:

Can you please clarify if the concrete block is to be painted? Are the steel HSS frames to be painted? (If so, are they painted already?) Is the mesh to be painted? There is a spec section for the painting of block and steel but it states for the painting of all items indicated, but it only indicates the doors and frames.

A:

Refer to Addendum No. 01, Section 09 91 00 - Painting for a revised finish coating system for concrete block.

Refer to Addendum No. 01, Section 05 12 23 - Structural Steel for Buildings: Galvanized mesh is not to be painted but welds to be touched-up with zinc-rich paint after installation.

Refer to Addendum No.01, Section 05 50 01 - Metal Fabrications: Doors and frames to be painted in accordance with Section 09 91 00, paragraphs 2.2.1/2.3.3. Other items to be painted according to systems listed in Section 09 91 00, unless indicated otherwise.

Q:

Are we to assume that the quantity of materials in the spec are the numbers we go with due to the short time frame and that we cannot verify what is there.

A:

Yes, assume that quantities of materials already on site, as listed in the specifications and on the drawings, are accurate.

ADDENDUM No.01, dated 2012-10-31.

This Addendum shall form part of documents referred to in "Articles of Agreement" as "Plans and Specifications".

The Plans and Specifications are amended as follows:

**SPECIFICATIONS**

**ARCHITECTURAL:**

	TEMPORARY BARRIER AND ENCLOSURES	Section 01 56 00 2012-09-28
--	-------------------------------------	--------------------------------

1.2 HOARDING                      1.    Delete article 1.2 in its entirety.

	STRUCTURAL STEEL FOR BUILDINGS	Section 05 12 23 2012-09-28
--	-----------------------------------	--------------------------------

Delete this Section in its entirety.

	METAL FABRICATIONS	Section 05 50 01 2012-09-28
--	--------------------	--------------------------------

2.1 MATERIALS                      1.    Paragraph 2.1.10: Add ", galvanized." at  
the end of the Paragraph.

3.3 SEGREGATION YARD  
ENCLOSURE                      1.    Add paragraph 3.3.4:  
".4    Touch-up welds with zinc-rich primer."

	PAINTING	Section 09 91 00 2012-09-28
--	----------	--------------------------------

2.3 EXTERIOR  
MATERIAL AND SYSTEM                      1.    Delete Paragraph 2.3.1.1 in its entirety  
and replace with the following:

".1 EXT 4.2H: Water repellent non-paintable  
finish. (not for use on light weight block)."

2. Delete Paragraph 2.3.2 in its entirety.

3.1 NEW SURFACES  
PREPARATION

1. Delete Paragraph 3.1.1.4 in its entirety.

End of Addendum No.01 dated 2012-10-31 consisting of 2 pages.