

The following changes to the tender documents are effective immediately and will form part of the contract documents:

## **1.0 SPECIFICATIONS**

- 1.1 Section 26 05 32  
Outlet Boxes, Conduit Boxes and Fittings
- .1 Item 2.5.1: ADD the following sentence "Acceptable Equal : RACO product marketed by Hubbell"
- 1.2 Section 09 80 00  
Acoustic Treatment
- .1 Item 2.1.2 : ADD the following sentence "Acceptable Product : Echotrol Acoustic Panel"

## **2.0 DRAWINGS**

- 2.1 Structural Drawing W-S01.1 – Typical Notes
- .1 REMOVE notes #9, #10 & #11 under the "(Piles) Foundation".
- 2.2 Structural drawing W-S02.1 – Pile Layout Plan
- .1 REMOVE notes #3 & #4 under the "Concrete end Bearing Pile Schedule"
- 2.3 Structural drawing W-S02.2 – Grade Beam Layout Plan
- .1 'GB9' on the "Concrete Grade beam Schedule" is to indicate 2200mm deep grade beam not 2000mm deep.
- 2.4 Architectural drawing W-A27 – Garage Plan & Details
- .1 REMOVE reference to "150mm" slab on grade INSERT "200mm" slab on grade.