

**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS À:**  
**Public Works Government Services Canada- Bid  
Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 421**  
**Saint John**  
**New Brunswick**  
**E2L 2B9**

## **SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### **Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Public Works Government Services Canada- Bid  
Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 421**  
**Saint John**  
**New Bruns**  
**E2L 2B9**

<b>Title - Sujet</b> Const.Svcs, Westmorland Inst, N.B.	
<b>Solicitation No. - N° de l'invitation</b> EC016-132714/A	<b>Amendment No. - N° modif.</b> 016
<b>Client Reference No. - N° de référence du client</b> R.043939.001	<b>Date</b> 2013-02-05
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWB-020-3192	
<b>File No. - N° de dossier</b> PWB-2-35125 (020)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-02-12</b>	<b>Time Zone</b> Fuseau horaire Atlantic Standard Time AST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Donovan, Janine PWB	<b>Buyer Id - Id de l'acheteur</b> pwb020
<b>Telephone No. - N° de téléphone</b> (506) 636-5347 ( )	<b>FAX No. - N° de FAX</b> (506) 636-4376
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

This Tender Amendment No. Sixteen (16) is raised to include the following Addendum No. Sixteen (16).

The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

**All other terms and conditions remain the same.**

Addendum No. 16.

**1. SPECIFICATION**

**1. Section 11 13 00 - LOADING DOCK EQUIPMENT: REVISE Paragraph 2.2.1**

"Dock Bumpers: Laminated rubber type; Size and configuration as indicated.

.1 Quantity: As indicated.

.2 Acceptable Manufacturers: Blue Giant, Super Seal."

**2. Section 11 13 00 - LOADING DOCK EQUIPMENT: DELETE Paragraph 2.2.2**

**3. Section 11 13 00 - LOADING DOCK EQUIPMENT: DELETE Paragraph 2.2.3**

**4. Section 10 26 00.01 - WALL AND CORNER GUARDS: ADD Paragraph 3.3.4**

"Install corner guards to all external corners of gypsum board finished partitions."

**5. Section 07 61 00 - SHEET METAL ROOFING: REPLACE Paragraph 2.3.1**

"Snow Guards: Provide manufacturer's sliding snow retention system to locations indicated on Drawings. The system shall be engineered to suit local environmental and climatic conditions, and be secured to the structural steel frame."

**6. Section 07 61 00 - SHEET METAL ROOFING: REPLACE Paragraph 3.2.8**

"Install snow guard system in accordance with approved Shop Drawings."

**7. Section 01 56 00 - TEMPORARY BARRIERS AND ENCLOSURES: ADD Paragraph 1.3.2.1**

---

"Swing Gate Posts for entrances shall be set in concrete footings. Footings depth to be set below frost line. Form footings using prefabricated footing forms, minimum diameter 200 mm. Provide 25 MPa concrete to footings, crown top to shed water."

## **2. DRAWINGS**

**1. Drawing 1,2&4/A300 - ELEVATIONS:** Snow guards shown in elevations represent location only, and do not represent type or system given the revision to Sheet Metal Roofing (Refer to Addendum 7). Snow Guards: Provide manufacturer's sliding snow retention system to locations indicated on Drawings. The system shall be engineered to suit local environmental and climatic conditions, and be secured to the structural steel frame. Install snow guard system in accordance with approved Shop Drawings.

## **3. QUESTIONS AND ANSWERS**

Q1: Who's responsible for painting masonry, structural steel and any exterior painting?

A1: Priming and finish painting of interior gypsum board walls and ceilings and metal doors and frames will be performed by the Owner's own forces. Schedule and coordinate work performed by the Owner to not cause delays in the Work (refer to Addendum 7). All other painting by Contractor. For further clarification, the concrete block wall along gridline B will not be painted. We do not have any exterior painting except for bollards.