

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet Saint John Steel Sheet Pile Repair	
Solicitation No. - N° de l'invitation E0227-130927/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client R.051108.001	Date 2012-07-27
GETS Reference No. - N° de référence de SEAG PW-\$PWB-004-3099	
File No. - N° de dossier PWB-2-35033 (004)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-08-02	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Doucet, Gisele PWB	Buyer Id - Id de l'acheteur pwb004
Telephone No. - N° de téléphone (506) 636-4541 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Tender Amendment No. Three (3) is being issued to include the following questions and answers.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 3.

QUESTIONS AND ANSWERS

Q1. Can you please confirm the size of plate required cover existing holes thru the sheet pile wall. On "Section of Work" and section "A" on drawing 3 of 4 it is noting 32mm thick steel plate. Also is this plate to be continuous for entire length of work area and as noted on drawing 3 of 4 in "Section of Work".

A1. The function of the plate is just to cover the holes when you form so you don't lose the concrete. It is 3.2mm (1/8inch) thick. As it is just patching the holes, it is not continuous. It is recommended that you go to site at low tide and become familiar with the extent of the holes.

Q2. Can you provide length of 150 x 150 x 19 angle clip required to support continuous timber spacer as detailed on drawing 3 of 4 in "Section of Work" and on drawing 4 of 4 in "Plan View" and section "B".

A2. Each is 300mm long.

Q3. What is the sizing of the continuous timber spacer? On drawing 4 of 4 in section "A" and "B" it notes 200 x 200 but detail shows corners beveled. Does this mean the timber is dressed 4 sides or are we to use rough timber to full 200 x 200 size?

A3. 200 x 200 is the nominal size. The actual dressed dimension would be approx 190x190.