

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving - PWGSC / Réception des soumissions -
TPSGC
11 Laurier St./11 rue Laurier
Place du Portage, Phase III
Core 0A1 / Noyau 0A1
Gatineau, Québec K1A 0S5

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Construction Services Division/Division des services de
construction
11 Laurier St./11 Rue Laurier
3C2, Place du Portage
Phase III
Gatineau, Québec K1A 0S5

Title - Sujet FIRE ALARM/VOICE COMM SYS. REPLACE.	
Solicitation No. - N° de l'invitation EP067-133336/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client 20133336	Date 2013-04-25
GETS Reference No. - N° de référence de SEAG PW-\$\$FG-356-62581	
File No. - N° de dossier fg356.EP067-133336	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-05-07	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lagacé, Hélène	Buyer Id - Id de l'acheteur fg356
Telephone No. - N° de téléphone (819) 956-0060 ()	FAX No. - N° de FAX (819) 956-8335
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment No. 1 is issued to:

1. to incorporate the following Notice:

IMPORTANT NOTICE TO SUPPLIERS

Government of Canada is moving its Government Electronic Tendering Service from MERX to Buyandsell.gc.ca/tenders on June 1, 2013

Starting June 1, 2013, federal government tenders (tender notices and bid solicitation documents) will be published and available free of charge on a Government of Canada Web site on Buyandsell.gc.ca/tenders.

The Government Electronic Tendering Service on Buyandsell.gc.ca/tenders will be the sole authoritative source for Government of Canada tenders that are subject to trade agreements or subject to departmental policies that require public advertising of tenders.

Get more details in the Frequently Asked Questions section of Buyandsell.gc.ca/tenders.

After June 1, 2013, all tenders and related documents and amendments will be on Buyandsell.gc.ca/tenders.

On June 1, 2013, suppliers must go to Buyandsell.gc.ca/tenders to check for amendments to any tender opportunities that they have been following on MERX prior to June 1.

Bookmark Buyandsell.gc.ca/tenders now to be ready for June 1!

2. to issue Addendum No. 1

Solicitation No. - N° de l'invitation

EP067-133336/A

Client Ref. No. - N° de réf. du client

20133336

Amd. No. - N° de la modif.

001

File No. - N° du dossier

fg356EP067-133336

Buyer ID - Id de l'acheteur

fg356

CCC No./N° CCC - FMS No/ N° VME

ADDENDUM NO. 1

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

DRAWINGS

1. DRAWING E0-01 – Title Sheet, Electrical Legend and General Notes

.1 Add the following note to “General Notes”

“Fire alarm system is to be cleared of all trouble/alarm for the duration of the construction.”

2. DRAWING E0-02 – New Fire Alarm Riser Diagram

.1 The fire alarm devices are connected to the DGP as noted on the drawing, note number 2.

.2 The following is a list of circuits connected to the DGP:

- DGP NODE 2 / BYT-P2 = 4 circuits
- DGP NODE 3 / RID-T = 12 circuits
- DGP NODE 4 / RID-2 = 4 circuits
- DGP NODE 5 / BYT-T1 = 8 circuits
- DGP NODE 6 / BYT-T2 = 11 circuits
- DGP NODE 7 / BYT-1 = 4 circuits
- DGP NODE 8 / SUS-T = 15 circuits

ALL OTHER TERMS AND CONDITIONS WILL REMAIN THE SAME.