

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**
Public Works and Government Services Canada
Telus Plaza North/Plaza Telus Nord
10025 Jasper Ave./10025 ave. Jaspe
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
Telus Plaza North/Plaza Telus Nord
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Fencing Contractor	
Solicitation No. - N° de l'invitation EW038-131918/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client PWGSC 20131918	Date 2012-11-16
GETS Reference No. - N° de référence de SEAG PW-\$PWU-011-9601	
File No. - N° de dossier PWU-2-35277 (011)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-11-20	Time Zone Fuseau horaire Mountain Standard Time MST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Hugo (RPC), Tammey	Buyer Id - Id de l'acheteur pwu011
Telephone No. - N° de téléphone (780) 497-3917 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EW038-131918/A

Amd. No. - N° de la modif.

002

Buyer ID - Id de l'acheteur

pwu011

Client Ref. No. - N° de réf. du client

PWGSC 20131918

File No. - N° du dossier

PWU-2-35277

CCC No./N° CCC - FMS No/ N° VME

Les changements suivants dans les documents d'appel d'offres sont en vigueur immédiatement.
Cet addendum feront partie du cahier des charges. Voir ci-joint

Specifications for:

Private Family Visitation Containment

Edmonton Institution
Edmonton, Alberta

Correctional Service Canada

PROJECT # R.058797.001



ADDENDUM #02
November 16, 2012

Issued by HFKS Architects Inc.

Addendum #02 comprises:

1. Architectural Text (Specifications): 1 pages

This Addendum makes amendments to the Tender Documents for the "Correctional Services Canada: **Private Family Visitation Containment**" project.

This Addendum forms part of the Contract Documents and is to be read, interpreted and coordinated with all other parts. The cost of all Work contained herein shall be included in the Contract Price. Items listed under the Specifications in this Addendum and having influence on the Drawings are so deemed to alter the Drawings. The amendments modify the Contract Documents as follows:

1. ARCHITECTURAL TEXT

**ITEM #1: REFERENCE: ARCHITECTURAL TENDER DRAWING #A101 –
ARCHITECTURAL INFORMATION.**

- .1 Add GENERAL NOTES section to read:

1. All concertina wire to be in loops of 710mm diameter.

- .2 Revise keynote 2.1 to read as follows:

Existing 1800mm tall fence and components to be demolished and removed from site **including complete removal of fence post piles. Infill all voids remaining as a result of the removal of piles. Replace finished surface to match existing.**

**ITEM #2: REFERENCE: ARCHITECTURAL TENDER DRAWING #A103 – ELEVATIONS
AND SECTIONS.**

- .1 Clarification as to the intent of Detail #5 "TYPICAL SECTION OF REINFORCED CONCRETE MOWING STRIP":

1. The top of the mowing strip does not require a flat portion as shown in the contract documents. It is acceptable to have the top of the mowing strip slope (at 2%) to a single high point in the middle such that water will still be shed from the mowing strip in either direction. The dimensions and required clearances as per the contract documents still govern.

END OF ADDENDUM #02