
Public Works and
Government Services
Canada

Prince Albert, SK
Saskatchewan Penitentiary, Riverbend
Institute, Electrical Services, B4, UNIT 6,
and F25 - File Storage Renovations

Addendum No. 1
Page 1 of 1

Project No.: R.043477.001

May 10, 2013

The following changes to the tender documents are effective immediately and will form part of the contract documents:

INSERT

Wire and connect rolling fire shutter as required. Wire to a new 15A-1P circuit breaker in nearest available panel. Provide two(2) smoke detectors within 1.5m of each side. Tie into fire alarm system to release upon smoke detector activation. Refer to "Installation of Fire Alarm Systems - CAN/ULC-S524-06" for mounting details.