

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet St.Andrews Bio.S.,Demo/New Site Wor	
Solicitation No. - N° de l'invitation E0227-122966/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client R.000067.011	Date 2012-03-27
GETS Reference No. - N° de référence de SEAG PW-\$PWB-004-3055	
File No. - N° de dossier PWB-1-34204 (004)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-04-05	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Doucet, Gisele PWB	Buyer Id - Id de l'acheteur pwb004
Telephone No. - N° de téléphone (506) 636-4541 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Tender Amendment Number Six (6) is raised to provide revisions and clarifications as noted below.

The following amendment to the tender documents is effective immediately. This Addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 6

1. Reference: Item #9 of Addendum #3.

- Delete the supply of 100 HID image-printable cards.
- The proximity readers to be supplied should be KANTECH, HID ProxPoint Plus type units.

2. Reference: PCM No. 37 Bound into Specification at the end of Volume No. 2

- Balancing Value: Manufacturer: T.A. Hydronics
Model Number: STAD-3/4

3. LEED requirements for demolition waste disposal: There is no need to comply with LEED. The Contractors may salvage only the material they wish to salvage.

4. The Contractor shall supply, install, and commission all labour and material required to carry out the following additional work to the Contract:

1. Item 2.1: As per notes 2 and 12.6 on Drawing E003, the PVC conduits run under the wharf from the pump house to the net shed have been mostly removed due to current renovation to the wharf. The Phase 4 Penhallow Demolition Contractor is to supply and install new 53mm PVC conduit under the wharf c/w 316 grade stainless steel clamps and bolts from the pump house to the net shed c/w two (2) 6-pair telephone cables terminated at each end.

2. On Drawing E001 and E002, the fibre optic cable to the Esther Lord Building will not handle the new camera on the north west corner of the Esther Lord Building, so the camera will be relocated to the south east corner of the existing Generator Building c/w all power and cable requirements and connected into the 4th channel of the new encoder in the Generator Building.

3. In Addendum #3, Item 10.1.3, the new 50M 6-strand fibre optic cable is to run from the Medcof Building (Museum)/Samples Storage Building fire alarm panel overhead

Solicitation No. - N° de l'invitation

E0227-122966/A

Amd. No. - N° de la modif.

006

Buyer ID - Id de l'acheteur

pwb004

Client Ref. No. - N° de réf. du client

R.000067.011

File No. - N° du dossier

PWB-1-34204

CCC No./N° CCC - FMS No/ N° VME

on pole P4A and P4 and then underground in existing 103mm conduit to the Lauzier Building HUB and be connected to existing fibre cable running to the new Wet Lab/Science Building fire alarm panels.