

**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS À:**  
**Public Works Government Services Canada- Bid  
Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 421**  
**Saint John**  
**New Brunswick**  
**E2L 2B9**

## **SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### **Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Public Works Government Services Canada- Bid  
Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 421**  
**Saint John**  
**New Bruns**  
**E2L 2B9**

<b>Title - Sujet</b> Saint John,Postal Sta A,Heat Pump	
<b>Solicitation No. - N° de l'invitation</b> E0227-131562/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> R.053638.001	<b>Date</b> 2012-10-24
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWB-004-3149	
<b>File No. - N° de dossier</b> PWB-2-35082 (004)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-10-30</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Atlantic Daylight Saving Time ADT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Doucet, Gisele PWB	<b>Buyer Id - Id de l'acheteur</b> pwb004
<b>Telephone No. - N° de téléphone</b> (506) 636-4541 ( )	<b>FAX No. - N° de FAX</b> (506) 636-4376
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

This Tender Amendment No. Two (2) is raised to include the following revisions.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 2.

## 1. **SOLICITATION DOCUMENT**

### **SI09 Security Clearance**

**REMOVE,**

1. **At bid closing, the Bidder must hold a valid** [as per clause 1 of the security clauses: i.e. Designated Organization Screening (DOS) / Facility Security Clearance at level of SECRET/TOP SECRET] as indicated in section SC01 of the Supplementary Conditions. Failure to comply with this requirement will render the Bid non-compliant and no further consideration will be given to the Bid.

And **REPLACE WITH,**

1. **Prior to award of Contract, the Bidder must hold a valid** Designated Organization Screening (DOS) at level of **Reliability Status** as indicated in section SC01 of the Supplementary Conditions. Failure to comply with this requirement will render the Bid non-compliant and no further consideration will be given to the Bid.

## 2. **QUESTIONS AND ANSWERS**

**Q1:** What brand and type of panels are in the building as well as the locations? Also, is there a schedule of what size breakers are associated with each heat pump?

**A1:** There are electrical panels located on each floor.

There are two types of panels.

1) Federal Pioneer (PW0, PW1, PW3, PW4 & PW5)

2) Siemens (PW2)

There is no breaker size schedule. The breakers are 15, 20 & 30 amps.

Solicitation No. - N° de l'invitation

E0227-131562/A

Amd. No. - N° de la modif.

002

Buyer ID - Id de l'acheteur

pwb004

Client Ref. No. - N° de réf. du client

R.053638.001

File No. - N° du dossier

PWB-2-35082

CCC No./N° CCC - FMS No/ N° VME

---