

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**
Regional Manager/Real Property
Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Regional Manager/Real Property Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

Title - Sujet Campbellford, ON Warkworth Institut	
Solicitation No. - N° de l'invitation EQ734-133174/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client R.019591.001	Date 2013-03-18
GETS Reference No. - N° de référence de SEAG	
File No. - N° de dossier PWL-2-35139 (039)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-03-21	
Time Zone Fuseau horaire Eastern Daylight Saving Time EDT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Hassell, Bob	Buyer Id - Id de l'acheteur pwl039
Telephone No. - N° de téléphone (416) 590-8270 ()	FAX No. - N° de FAX (416) 512-5862
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Correctional Service Canada Warkworth Institution 15847 County Road 29 Campbellford, ON K0L 1L0	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

QUESTIONS AND ANSWERS

Question 33.

33. Given the magnitude of this project it will be challenging to put forth a reasonable and accurate quote within a seven day period. The timeframe between the site walkthrough and the closing is insufficient, and we are requesting an extension to March 28th allowing adequate time to prepare a proper cost assessment of the project.

Answer 33.

Original bid closing date remains.

Question 34.

Will space be allocated on site for storage and set up of a temporary office for the duration of the project?

Answer 34.

Under certain conditions use of a designated compound may be possible, plan for lay down area use only for a 'C' can type of unit.

Question 35.

Will there be onsite facilities that our employees will have access to?

Answer 35.

Previous contractors have supplied their own portable units either at their storage area or on a trailer on site removed daily.

Question 36.

Will there be a designated area our employees can use for lunch and breaks?

Answer 36.

No, as this is a non smoking facility most contractors have their lunch breaks at their respective storage area.

Question 37.

If we are to provide our own trailers and washroom facilities, will hydro and potable water made available to us to hook up to?

Answer 37.

No

Question 38.

How will we be given access into inmate occupied area such as cells, will the inmates be cleared out allowing our workers safe access to the cell and corridors?

Answer 38.

The inmates will still be in their living units, commissionaires and a correctional staff member will be in attendance.

Question 39.

Will there be guards allocated to us specifically during the work day for access into and out of areas?

Answer 39.

Commissionaires will accompany contractors at all times within the institution.

Question 40.

Who will be obtaining the building permit for this project?

Answer 40.

The General Contractor.

Question 41.

Can we get the names of all the companies that attended the walkthrough?

Answer 41.

No

Question 42.

Once work begins are we have access to multiple buildings at the same time?

Answer 42.

Yes, subject to availability of commissionaires, as indicated in previous answer to question 8.

Question 43.

Are there any restrictions on the amount of manpower we can have working on site throughout the course of the day?

Answer 43.

Yes, subject to availability of commissionaires, as indicated in previous answer to question 8.

Question 44.

Are the existing initiating and signalling zones and circuits Class "A", or Class "B"?

Answer 44.

The wiring configuration of the existing fire alarm system is unknown. However, there are a number of end-of-line resistors, which would indicate Class B wiring in those places. The end of line resistors and wiring are to be removed.

Question 45.

Are there a set of AsBuilt drawings that we can reference prior to closing of this tender

Answer 45.

No. Contractor to review the Contract Plans and Specs.

Question 46.

Will cell blocks be vacant during install of fire systems in that area.

Answer 46.

This is not in the planning

Question 47.

Due to the magnitude of the size of this project would an extension to the closing date be added to allow more time.

Answer 47.

No, original bid closing date remains.

Question 48.

Can open excavations at days end be fenced for the night or does each trench have to be filled in.

Answer 48.

Open excavations are not permitted at end of workday, can be covered by metal plates though

Question 49.

Can granular materials / soil be stocked inside compound.

Answer 49.

No

Question 50.

As noted we are instructed to re-use existing conduit, does this include flex and or armored FAS cable as may be required?

Answer 50.

Flexible conduit may be reused if appropriate and in good condition. Existing wiring including armored FAS cable is to be removed.

Question 51.

Due to the existing building construction, many of the detector locations will prevent a typical in/out class 'A' conduit system. Are there requirements to separate/space out existing or new conduit installations?

Answer 51.

Yes, field device wiring is to be separated per CAN/ULC-S524-06, including section 3.3.1.3, other than in those places where the exceptions listed in that standard would apply.

Question 52.

What is the requirement to maintain the existing fire alarm system?

Answer 52.

Refer to specification section 01 11 00 1.7.1, Work Sequence.

Question 53.

Are there ground water testing reports for all areas within the excavation scope?

Answer 53.

Refer to the submittals listed in section 31 23 33.01 1.3.

