

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**

Regional Manager/Real Property
Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Regional Manager/Real Property Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

Title - Sujet Campbellford, ON Warkworth Institut	
Solicitation No. - N° de l'invitation EQ734-133174/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client R.019591.001	Date 2013-03-19
GETS Reference No. - N° de référence de SEAG	
File No. - N° de dossier PWL-2-35139 (039)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-03-21	
Time Zone Fuseau horaire Eastern Daylight Saving Time EDT	
F.O.B. - F.A.B.	
Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Hassell, Bob	Buyer Id - Id de l'acheteur pwl039
Telephone No. - N° de téléphone (416) 590-8270 ()	FAX No. - N° de FAX (416) 512-5862
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Correctional Service Canada Warkworth Institution 15847 County Road 29 Campbellford, ON K0L 1L0	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

QUESTIONS AND ANSWERS

Question 54.

Class A loop wiring requires specific (safe) distance between supply and return runs that will be difficult if not impossible to achieve in the inmate building corridors (4 accommodation buildings – typical corridor).

Answer 54.

Class A Circuit Wiring Installation is required in these areas.

Question 55.

Also one of the previous questions was referring to conduits use. In my recollection ceilings at all corridors in accommodation buildings are located less than 2400mm – could you please provide actual heights in these corridors and cells

Answer 55.

Ceiling heights in the various cells and corridors is not known.

Question 56.

Section 27 10 05 1.3.1 indicates work for voice (telephone), data and image for occupants telecommunication systems but it is not indicated on the drawings.

Answer 56.

Refer to the Notes on Drawing E-121 regarding demolition associated with the existing telephone system.

Question 57.

In addendum #2 it was indicated that contractors should use all counts from the floor plans and not from single line diagram. As it happens many devices are only shown on the single line diagram like: LIM, Single and Dual Input Modules,

Answer 57.

Line Isolator Modules(LIMs) are not shown on floor plans. Refer to the Riser Diagrams and Note 15 on sheet E-1. Dual Input Modules and Relay Modules are not shown on floor plans. Refer to the Riser Diagram.