

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet Const.Svc,14 Bed Live Unit,Nova Ins	
Solicitation No. - N° de l'invitation EC016-133509/A	Amendment No. - N° modif. 007
Client Reference No. - N° de référence du client R.043957.001	Date 2013-04-25
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3237	
File No. - N° de dossier PWB-2-35164 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-04-30	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Tender Amendment No. Seven (7) is raised to include the following Addendum No. Seven (7).

The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 7.

1. SPECIFICATIONS

.1 Reference Specification Section 01 50 00:

.1 Delete Clause 1.6.2.3, 'posts to be sunk minimum..' and replace with the following:

“.3 Posts to be driven minimum 600mm into the ground. Concrete footings are not permitted”

.2 Reference Specification Section 07 21 13:

.1 Add paragraph 2.1.1 to read as follows and renumber accordingly:

“.1 Expanded Polystyrene Insulation

.1 Expanded to CAN/ULC-S701

.2 Type 3

.3 Required RSI value 1.76.

.4 Insulation value thickness per inch based on value listed in the latest edition of NRC - Evaluation listing.”

.2 Revise paragraph 2.2.1 to read as follows:

“.1 Extruded Polystyrene Insulation / Expanded Polystyrene Insulation:”

.3 Revise paragraph 2.2.1.1 to read as follows:

“.1 Extruded / Expanded to CAN/ULC-S701”

.4 Revise paragraph 2.4.1 to read as follows:

“.1 Extruded Polystyrene Insulation / Expanded Polystyrene Insulation:”

.5 Add paragraph 2.4.1.2 to read as follows and renumber accordingly:

“.2 Expanded to: CAN/ULC-S701, Type 3”

2. **DRAWINGS**

.1 **Reference Drawing A-004 - Wall and Finish Schedule:**

- .1 1/004 - Delete reference to 'SC-SEALED CONCRETE (EPOXY FLOORING)' in the Legend section of the Finishes Schedule and replace with 'C1-EXPOSED CONCRETE'
- .2 1/004 - Delete all references to 'SC-1' in the Schedule items and replace with 'C1'

.2 **Reference Drawing A-103 - Level 1 Reflected Ceiling Plan:**

- .1 1/103 - In Rooms 114 (Mechanical Room), 116 (Electrical Room) and 115 (Lan Room), the ceilings are to receive spray-on fire proofing only, as noted on drawings. These 3 rooms **DO NOT** receive the rock wool foil faced insulation as noted on Drawing A-001, Floor Type Legend. (Type F2).

3. **QUESTIONS AND ANSWERS**

Q1: Is there any asphalt work required?

A1: Asphalt is mentioned in section 32 98 00 Reinstatement (patching if they have to cut into the existing asphalt).

Q2: Reference Addendum # 4 Section 3. Drawings .01 and Section 07 46 13-2.2 - Please advise what soffit material to be used as section 07 46 13 2.1 was deleted as of Addendum # 4.

Reference Addendum # 4 Section 3. Drawings .4 and Section 07 61 00 2.6 - Please advise what soffit material to use as the products specified are Metal and the addendum #4 states to use aluminum soffit.

A2: Our addendum #4 struck out section 2.1 (Vertical metal cladding) and directed the bidders to use section 2.2 for the soffit.

Addendum #4 does not say that the soffit is to be Aluminum, neither does 07 46 13 section 2.2. The material is to be perforated steel.

Solicitation No. - N° de l'invitation

EC016-133509/A

Client Ref. No. - N° de réf. du client

R.043957.001

Amd. No. - N° de la modif.

007

File No. - N° du dossier

PWB-2-35164

Buyer ID - Id de l'acheteur

pwb020

CCC No./N° CCC - FMS No/ N° VME

Q3: Refer to Division 10, Part 2 Products, 2.1 Room Signage

Supply and install room signage. "Design provided by departmental representative".

Can you supply this sign layout for pricing purposes?

A3: Signage is shown on dwg A-005. See Room Identifier 5/A-005.

4. **SOLICITATION DOCUMENTS**

Supplementary Conditions - **DELETE** SC01 Asphalt Cement Price Adjustment