

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, 2nd floor
800, rue Burrard, 2e étage
Vancouver
British Columbia
V6Z 2V8
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, 12th floor
800, rue Burrard, 12e étage
Vancouver
British C
V6Z 2V8

Title - Sujet Cell Call & GFCI Replacement	
Solicitation No. - N° de l'invitation EZ899-132991/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client	Date 2013-03-07
GETS Reference No. - N° de référence de SEAG PW-\$PWY-005-6909	
File No. - N° de dossier PWY-2-35321 (005)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-03-11	Time Zone Fuseau horaire Pacific Standard Time PST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Pillay, Sal (PWY)	Buyer Id - Id de l'acheteur pwy005
Telephone No. - N° de téléphone (604) 775-9386 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CSC - Matsqui Institution, Abbotsford, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EZ899-132991/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

006

File No. - N° du dossier

PWY-2-35321

Buyer ID - Id de l'acheteur

pw005

CCC No./N° CCC - FMS No/ N° VME

Refer to the attached Addendum No. 3 dated 07 March 2013.

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

Answers (A) to Questions (Q) Received

- Q.1** The Planet SCSW Series indicated in Addendum #2 in response to question Q.5 is not a layer 3 switch. Planet equivalent solution might be: XGS3-24042 with HPOE-2400G 30W per port injector. Please approve.
- A.1** *Replace Planet SCSW Series network switch noted in Addendum #2 with the one noted in the question above. In addition, replace Allied Telesis 8100S Series network switch noted in the same addendum with Allied Telesis x610 Series.*
- Q.2** There is mention of relief exhaust fans (ventilation of air in work occupied areas). How are we to duct out the building? There is a mention of replacing used air filters. Seems quite vague, can we make this as a cash allowance?
- A.2** *In general, the building HVAC must be protected from dust and contaminants during construction. Temporary exhaust routes to be determined on how the construction area must be ventilated and this must be approved by the Departmental Representative. All HVAC filters of the AHUs to the area of construction are to be replaced after completion of the project. See also further explanations to page 7 of Specification Section 01 01 50 attached to this addendum.*
- Q.3** What is the thickness of the steel plate in building M2d?
- A.3** *Thickness of existing still plating in Seg. Unit M2d is 4.8mm.*
- Q.4** Are the five spare POE Network Switches 24-port or 48-port? There is a considerable price premium for 48 port switches.
- A.4** Three (3) 24-port and two (2) 48-port.
- Q.5** The supplier of the Cell Call System would like to confirmation that the warranty period for the system is 12 months.
- A.5** *The required warranty for Cell Call System is 12 months.*

Answers (A) to Requests Received for Approval of Alternate Products (AP)

- AP.1** Intercom capable Cell Call System: Alternate solution by interfacing Harding ICE 600 speaker/push bottom assembly to Essex Electronics RoxProx PRX-2G CCD and using one single Ethernet connection to both intercom capable COD and IP CCD.
- A.1** The above solution is not acceptable to CSC as it would require additional cost to future projects in the Institution.

END OF ADDENDUM No. 3

9 TEMPORARY UTILITIES

- .1 Installation and Removal:
 - .1 Provide temporary utilities controls in order to execute work expeditiously.
 - .2 Remove from site all such work after use.
- .2 Water supply:
 - .1 Existing water supply system may be used for construction purposes provided that damaged components are replaced when damaged. Provide own hoses from source.
- .3 Temporary Heating and Ventilation:
 - .1 Construction heaters used inside building must be vented to outside or be flameless type. Solid fuel salamanders are not permitted.
 - .2 Provide ventilation in enclosed areas as required to:
 - .1 Facilitate progress of Work.
 - .2 Provide adequate ventilation to meet health regulations for safe working environment.
 - .3 Maintain temperatures of minimum 10 degrees C in areas where construction is in progress.
 - .4 The air system will be in use during work of this contract inside existing building. Protect duct systems by filters inspected daily and replaced as necessary. During dust generating construction work block off all outlets and seal air tight.
 - .1 Before Substantial Completion comply with the following conditions:
 - .1 Remove all temporary duct covers.
 - .2 Replace used air filters with new filters.
- .5 Ventilating:
 - .1 Prevent accumulations of dust, fumes, mists, vapours or gases in areas occupied during construction.
 - .2 Provide local exhaust ventilation to prevent harmful accumulation of hazardous substances into atmosphere of occupied areas.
 - .3 Dispose of exhaust materials in manner that will not result in harmful exposure to persons.
 - .4 Ventilate storage spaces containing hazardous or volatile materials.
 - .5 Ventilate temporary sanitary facilities.
 - .6 Continue operation of ventilation and exhaust system for time after cessation of work process to assure removal of harmful contaminants.
- .6 Protect ducting system by filters inspected daily and replaced as necessary.
 - .1 Before Substantial Completion comply with the following conditions:
 - .1 Replace used air filters with new filters.
- .7 Maintain strict supervision of operation of temporary ventilating equipment to:
 - .1 Conform with applicable codes and standards.
 - .2 Enforce safe practices.
 - .3 Prevent abuse of services.
 - .4 Prevent damage to finishes.
 - .5 Vent direct-fired combustion units to outside.
- .8 Be responsible for damage to Work due to failure in providing adequate protection during construction.

This is a requirement

It may be possible to shut down an existing ventilation system in a given work area. If so this applies

If outlets are not sealed off this is a requirement and outlets must be covered with filters.

If portable units are outside this is not required

When duct systems cannot be shut down this applies

This is a requirement

In most cases a window can be used to ventilate an area using fans and flexible ductwork. Each building will need to be reviewed to determine course of action.

inside exist buildings or for temporary buildings outside.