

**BULK FUEL INSTALLATION INSPECTION
(Contracts)**

DATE _____

Canadian Forces CE Preventive Maintenance Inspection record	Work Order # _____				
	Sheet	1	of	2	

Item Inspected	Frequency					Done	Needs Repair
	M	Q	SA	A	AR		

System Area - General							
Insp. by BCEO or his authorized rep.	X					Y / N	
Annual insp. by BCEO				X		Y / N	

Bulk Storage Tanks							
Visual Inspection of tanks				X		Y / N	
Cleaning & repainting tanks					X	Y / N	
Inhibiting inactive tanks					X	Y / N	
Proper identification of tanks					X	Y / N	

Breather and Pressure Vacuum Vents							
Insp. breather vents	X					Y / N	
Overhaul breather vents			X			Y / N	
Insp. pressure vacuum vents	X					Y / N	

Pipelines							
Visual insp. all lines				X		Y / N	

Pumps							
General insp. pumping system	X					Y / N	
Carry out complete overhaul of pumps					X	Y / N	

Filters & Filter Dehydrators							
Clean filter compartment	X					Y / N	
Insp. of filters & filter dehydrators	X					Y / N	
Date of last filter change							

DISPENSER / TRANSITION SUMP							
Insp. of sumps	X						

Frequency Code		Comments
M	Monthly	
Q	Quarterly	
SA	Semi-Annually	
A	Annually	
AR	As Required	

SIGNATURE of POL Rep : _____

SIGNATURE of Inspector : _____

