

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
PO Box 1408, Room 100
167 Lombard Ave.
Winnipeg
Manitoba
R3C 2Z1
Bid Fax: (204) 983-0338

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Western Region
PO Box 1408, Room 100
167 Lombard Ave.
Winnipeg
Manitoba
R3C 2Z1

Title - Sujet Fire Alarm & Det Sys Thunder Bay	
Solicitation No. - N° de l'invitation W4M00-12T213/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client W4M00-12T213	Date 2012-03-15
GETS Reference No. - N° de référence de SEAG PW-\$WPG-208-7946	
File No. - N° de dossier WPG-1-34271 (208)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-03-21	Time Zone Fuseau horaire Central Standard Time CST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Hamp, Jordanna	Buyer Id - Id de l'acheteur wpg208
Telephone No. - N° de téléphone (204) 983-4460 ()	FAX No. - N° de FAX (204) 983-7796
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 002 is raised to address questions received by industry at the mandatory site visit held on 7 March 2012 and to modify Solicitation No. W4M00-12T213/A as follows:

QUESTIONS AND ANSWERS

Q. 1 On p. 2 of the Statement of Work it references a "Fire Protection Maintenance Manual" which is to be available at the office of the Site Authority. Is this available?

A.1 No, it is currently not available. DND will obtain this manual and will have it onsite.

Q.2 Are sprinkler systems included in the scope of work?

A. 2 No.

Q.3 Is the battery charging shop included in the scope of work?

A. 3 Yes. The battery shop is located at the Armoury. It must meet all criteria for all inspections applicable to the Armoury and the cost must be included in the inspections rates for the Armoury. See modification below.

Q. 4 Does the Thunder Bay Fire Code apply to the Contract?

A.4 No.

Q.5 Are inspection/testing/maintenance and repair services required for emergency and exit lights, fire hydrants, and fire extinguishers?

A.5 Inspection/testing/maintenance and repair services are required for emergency and exit lights. Fire hydrants and fire extinguishers are not covered in the scope of this Contract. See modification below.

MODIFICATIONS

M.1 Refer to p. 7, Part 4, Evaluation Procedures and Basis of Selection, Article 1.1.1. Mandatory Technical Criteria

DELETE: 1.1.1.1 Must be able to provide a minimum of one (1) certified journeyman electrician with fire alarm experience. Proof of certification will be required prior to Contract award.

INSERT: 1.1.1.1 Must be able to provide a minimum of one (1) certified sprinkler technician. Proof of certification may be required prior to Contract award.

M.2 Refer to p. 1, Annex A, Statement of Work, Article 2 SITE OF WORK

DELETE: Article 2 SITE OF WORK - in its entirety

INSERT:

2 SITE OF WORK

The work outlined herein pertains to fire detection fire alarm systems located in various buildings in Thunder Bay.

FACILITIES INCLUDED BUT NOT CONFINED TO:

Solicitation No. - N° de l'invitation

W4M00-12T213/A

Client Ref. No. - N° de réf. du client

W4M00-12T213

Amd. No. - N° de la modif.

002

File No. - N° du dossier

WPG-1-34271

Buyer ID - Id de l'acheteur

wpg208

CCC No./N° CCC - FMS No/ N° VME

BUILDING #	BUILDING NAME	TYPE OF SYSTEM
317 Park Street, Thunder Bay ON	Thunder Bay Armoury (including Battery Charging Shop)	Honeywell
N125 N Algoma Street, Thunder Bay ON	HMCS Griffon	Edwards
56 Marina Park Drive Thunder Bay ON	HMCS Griffon Boatshed	Edwards

M. 3 Refer to p. 1 Annex A, Statement of Work, Article 3.1

INSERT: Fire alarm systems include emergency and exit lights.

M.4 Refer to p. 1, Annex A, Statement of Work, Article 3.1.1.2

INSERT: Monthly scheduled services must be performed every second Thursday of the month between the hours of 1000 to 1100 at HMCS Griffon and the HMCS Griffon boat shed and between the hours of 1100 and 1200 at the Thunder Bay Armoury.

M.5 Refer to p. 1, Annex A, Statement of Work, Article 3.1.1 SCHEDULED SERVICES

INSERT: .1 A certified sprinkler technician will be required for the annual inspection to turn on and off the sprinkler valve

M. 6 Refer to p. 2, Annex A, Statement of Work, Article 3.1.2 AS AND WHEN REQUESTED SERVICES

INSERT: .3 The installation of any new electrical equipment required must be performed by a certified journeyman electrician.

M.7 Refer to p. 3, Annex A, Statement of Work

DELETE: Article 7 WORKMANSHIP - in its entirety and renumber articles accordingly.

M. 8 Refer to p. 18-19, Annex B, Basis of Payment, PRICING SCHEDULE 1 - SCHEDULED SERVICES, Option Year 1: 01 April 2013 to 31 March 2014 AND Option Year 2: 01 April 2014 to 31 March 2015, Items 4, 5, and 6

DELETE: Qty - 12

INSERT: Qty - 11

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.