

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Public Works Government Services Canada- Bid  
Receiving / Réception des soumissions  
189 Prince William Street  
Room 421  
Saint John  
New Brunswick  
E2L 2B9

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works Government Services Canada- Bid  
Receiving / Réception des soumissions  
189 Prince William Street  
Room 421  
Saint John  
New Bruns  
E2L 2B9

<b>Title - Sujet</b> New Water Transmission Main and Wel	
<b>Solicitation No. - N° de l'invitation</b> EC016-130976/A	<b>Amendment No. - N° modif.</b> 006
<b>Client Reference No. - N° de référence du client</b> R.000817.001	<b>Date</b> 2012-08-23
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWB-007-3109	
<b>File No. - N° de dossier</b> PWB-2-35041 (007)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2012-08-28</b>	<b>Time Zone</b> Fuseau horaire Atlantic Daylight Saving Time ADT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Ellis-Herring , Alison PWB	<b>Buyer Id - Id de l'acheteur</b> pwb007
<b>Telephone No. - N° de téléphone</b> (506) 636-3908 ( )	<b>FAX No. - N° de FAX</b> (506) 636-4376
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

Cette modification de l'invitation numéro 6 est soumise et comprend la modification suivante.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des documents de contrat.

Toutes autres conditions ne changent pas.

Modification numéro 6

## QUESTIONS ET RÉPONSES

Q1

Question on Butterfly Valves:

Specs section 23 05 23.05 page 2/3 item 1.6 Maintenance request 1 spare valve + a list of spare parts for each valve size. Are the spare parts necessary since you will have one spare valve of each size?

R1

No spare parts required but spare valves still required.

Q2

There are no specification on the hollow metal door or frame on drawing A01. Also they say to refer to the specifications for the hardware. Again, there are no specifications for the hardware. Can you please advise.

R2

Please find below information on doors, frames and door hardware for the above referenced project:

### **Doors and Frames:**

*Exterior doors will be weatherproof exterior insulated metal doors as manufactured by Apex Machine Works "AHI" or approved equal. Doors will be 20 gauge. They will be complete with 16 gauge pressed steel insulated frames, Apex or approved equal.*

*Steel hollow metal frames shall be 16 gauge base thickness of commercial grade steel to ASTM A525 with wiped zinc finish.*

### **Door Hardware – Single Door (Exterior):**

---

*Door hardware shall conform to the following schedule or approved equal (hardware per door):*

*3 ONLY HINGES FBB191 114 x 101 x NRP x C15*

*1 ONLY LOCKSET 7825-OB x C26D*

*1 ONLY DOOR CLOSER EN350-OZ x EN350-B DROP PLATE*

*1 ONLY HOLD OPEN DEVICE 590H x 26D*

*1 ONLY DOOR SWEEP W13S x DOOR WIDTH*

*1 ONLY SET WEATHERSTRIP W49 x SIZE TO SUIT*

*1 ONLY THRESHOLD CT39 x DOOR WIDTH*

Q3

Please advise on the following with regards to the hydrants Section 33 11 16 Page 5 of 18 2.3

Hydrants to open counter clockwise, threads to local standard, fittings to be internal lug quick-connect to CAN4-S543.

Question: Is the pumper a storz connection?

R3

A Storz connection will not be required for the fire hydrants on this project.

Q4

In regards to fire hydrants, if you are not aware, in the province of N.B. the nozzle threads either hose, or pumper nozzles on fire hydrants are different for most all municipality. A fire truck for instance from Fredericton could not connect to a fire hydrant from say Saint John, and vice versa. The question is, for hydrants at the Renous Prison, the nearest fire dept, (or municipality with a water system) to me would be the former Town of Newcastle, now City of Miramichi. Would that be the standard nozzle thread requirement for Renous....or would it be something else?

R4

These are flush hydrants not fire protection hydrants.