

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving - PWGSC / Réception des soumissions -
TPSGC
11 Laurier St. / 11, rue Laurier
Place du Portage, Phase III
Core 0A1 / Noyau 0A1
Gatineau, Québec K1A 0S5
Bid Fax: (819) 997-9776

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Electrical & Electronics Products Division
11 Laurier St./11, rue Laurier
6B1, Place du Portage, Phase III
Gatineau, Québec K1A 0S5

Title - Sujet CCVE CAMERA SYSTEM 3 PORTS	
Solicitation No. - N° de l'invitation 47005-137342/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client 1000307342	Date 2012-10-26
GETS Reference No. - N° de référence de SEAG PW-\$\$HN-334-61210	
File No. - N° de dossier hn334.47005-137342	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-11-01	Time Zone Fuseau horaire Eastern Daylight Saving Time EDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: McLaughlin, Michael	Buyer Id - Id de l'acheteur hn334
Telephone No. - N° de téléphone (819) 956-3622 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: See Herein	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This amendment is raised to address the following:

1) To answer questions raised by potential bidders.

1) The following questions were submitted to PWGSC , by the industry representatives in regards to this Solicitation. All questions are presented in their original language. PWGSC answers are presented in *Italic*. Offeror are recommended to read these Q & A and consider these while preparing their offer.

Q1) Can you please clarify the statement below? Is it really an aircondition unit inside the metallic rack?

"9.3. The storage server(s) must be placed in a locked metallic rack that meets CBSA security standards and contains an air conditioning unit to control the temperature."

A1) Yes, CBSA is looking for a rack that has an air cooling supply to deal with heating. As such, this means Air Conditioning.

Q2) On this RFP on Table 9- Storage Server Requirements #4. It was mentioned that the storage system must have an uninterruptable power supply (UPS) able to supply 60 minutes of power during outage, My observation on the site visit shows that you have Power generator on site which can supply power in case of power outage and you may only need a 15 minute UPS to bridge the gap between the UPS and the generator this will save the agency money on the cost of a UPS for 1 hour compared to the 15min UPS. Would this be acceptable?

A2) Yes, in this instance, a UPS reduction to 15 minutes would be acceptable.

Q3) The document mentions: 9.3. The storage server(s) must be placed in a locked metallic rack that meets CBSA security standards and contains an air conditioning unit to control the temperature. What are the CBSA security standards?

A3) Because this cabinet will be located within a lockable room the CBSA security standards will not apply.

ALL REMAINING TERMS AND CONDITIONS ARE UNCHANGED