

## 1. ARCHITECTURAL

### 1.1 SPECIFICATIONS

- .1 Section 01 91 00 Commissioning
  - .1 Delete line 1.24.1 "Contractor shall identify commissioning costs in his tender sum and should allocate not less than three percent (3%) of the total contract price for commissioning activities."
  - .2 Add to line 1.24.1 "Not used."
- .2 Section 02 32 00 Geotechnical Investigation
  - .1 Add Pavement Report
  - .2 Add Technical Memorandum, Additional Pavement Recommendations
- .3 Section 08 71 11 Finish Hardware
  - .1 Revise door 0108 to read: 0108A
  - .2 Add hardware door 0108B as follows:

1 PAIR OF DOORS                      0108B Exterior Electrical Room                      LHR/RHRA  
2/600mm x 2150mm x 45mm

FRAME TYPE: A

DOOR TYPE: B

HOLLOW METAL DOOR / HOLLOW METAL FRAME

2 EACH	CONTINUOUS GEARED HINGE	CFM83HD
1 SET	FLUSH BOLT	FB51P 626
1 EACH	MORTISE HOTEL LOCKSET	L9485L-03B 630
	WITH DEADBOLT 03B 630	
1 EACH	ABLOY CYLINDER	CY415N-TT0300-1 X GMK
1 EACH	KEYING	GMK TO BUILDING SYSTEM
2 EACH	DOOR CLOSER	4041XP 689
2 EACH	KICKPLATE W/TAPE	12 X DOOR WIDTH W/TAPE C32D
1 EACH	WEATHERSTRIP	W20N X 72in
2 EACH	WEATHERSTRIP	HEAVY DUTY SEALS X DOOR
		HEIGHT AL
7 FEET	DOOR GASKET	RUBBER DOOR GASKET - BLACK
1 EACH	THRESHOLD 36in	THRESHOLD X DOOR WIDTH AL
2 EACH	DOOR SWEEP	W24S X 36in AL
2 EACH	DOOR CONTACT	DOOR CONTACT - PREP - C/W
		JUNCTION BOX IN FRAME

NOTE:

Z astragal by hm door supplier

## 1.2 DRAWINGS

- .1 Reference Drawing A0.04 Door & Frames Schedule
  - .1 Refer to attached full-drawing re-issued
  - .2 Revise door 0108 to read: 0108A
  - .3 Add door 0108B as follows:

Door No:	0108B
Location:	Electrical to Outdoors
Size (mm):	2 x 610mm x 950mm
Door Type:	A
Door Material:	IHM
Door Finish:	PT1
Door Glass:	-
Fire Rating:	-
Frame Type:	A
Frame Material:	IHM
Frame Finish:	PT1
Frame Glass:	-
Wall Condition:	7/A6.17 & 6/A6.17
Specialty Hardware:	THT
Remarks:	Note #5
- .2 Architectural Drawing 1/A2.01 Main Floor Dimension Plan
  - .1 Refer to drawing ASK-01 (attached)
  - .2 Add new double doors 0108A adjacent to column A-2
  - .3 Add new partition as indicated adjacent to column.
- .3 Architectural Drawing 1/A2.06 Roof Plan
  - .1 Revise Roof Plan Code Legend Note #3 as follows:  
LOCATION OF VHF ANTENNA. REFER TO DRAWING 1/A6.19  
FOR DETAIL.
- .4 Architectural Drawing 1/A6.00 Plan Details - 1
  - .1 Refer to drawing ASK-02 (attached)
  - .2 Add new double doors 0108A.
  - .3 Revise plan detail for door jamb connection to partition.
- .5 Architectural Drawing 1/A4.01 Building Elevations - 2
  - .1 Refer to drawing ASK-03 (attached)
  - .2 Add new double doors to north elevation.
  - .3 Add code legend #DR2 to new doors.