

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions/Travaux
publics et Services gouvernementaux Canada
Building S-111
CFB Petawawa
Petawawa
Ontario
K8H 2X3
Bid Fax: (613) 687-6656

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada Supply
and Services Operation
Petawawa Procurement
Building S-111
CFB Petawawa
Petawawa
Ontario
K8H 2X3

Title - Sujet 1000 KW Load Bank	
Solicitation No. - N° de l'invitation W0107-12C422/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client W0107-12C422	Date 2013-01-25
GETS Reference No. - N° de référence de SEAG PW-\$PET-903-1216	
File No. - N° de dossier PET-2-37116 (903)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-01-31	Time Zone Fuseau horaire Eastern Standard Time EST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Harrington, Mary-Lou	Buyer Id - Id de l'acheteur pet903
Telephone No. - N° de téléphone (613) 687-0789 ()	FAX No. - N° de FAX (613) 687-6656
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

AMENDMENT NO. 3

1000 KW LOAD BANK

The Request for Proposal is hereby amended to answer questions received from a potential bidder as well as to make changes to the specification as follows:

1) Question #4 - After reviewing amendment #2 I see that it changed the kw requirement at 208V to not less than 300KW but in section 2.8.2.2 it still calls for testing at 1000KW at 208V, is this just a type O?

Answer #4 - At Annex "A", Statement of Requirement, section 2.8.2.2

DELETE 500KW load, 750KW load, 1000KW loading

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.