

RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services / Travaux
publics et services gouvernementaux
Kingston Procurement
Des Acquisitions Kingston
86 Clarence Street, 2nd floor
Kingston
Ontario
K7L 1X3
Bid Fax: (613) 545-8067

Revision to a Request for a Standing Offer

Révision à une demande d'offre à commandes

Regional Individual Standing Offer (RISO)

Offre à commandes individuelle régionale (OCIR)

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution

Public Works and Government Services / Travaux
publics et services gouvernementaux
Kingston Procurement
Des Acquisitions Kingston
86 Clarence Street, 2nd floor
Kingston
Ontario
K7L 1X3

Title - Sujet FIRE SUPPRESSION INSTALSTION		
Solicitation No. - N° de l'invitation W0114-11P047/A		Date 2012-10-04
Client Reference No. - N° de référence du client W0114-11-P047		Amendment No. - N° modif. 004
File No. - N° de dossier KIN-1-36534 (519)	CCC No./N° CCC - FMS No./N° VME	
GETS Reference No. - N° de référence de SEAG PW-\$KIN-519-5912		
Date of Original Request for Standing Offer Date de la demande de l'offre à commandes originale		2012-08-19
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-10-11		Time Zone Fuseau horaire Eastern Daylight Saving Time EDT
Address Enquiries to: - Adresser toutes questions à: Choquette, Herb		Buyer Id - Id de l'acheteur kin519
Telephone No. - N° de téléphone (613) 536-4874 ()	FAX No. - N° de FAX (613) 545-8067	
Delivery Required - Livraison exigée		
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:		
Security - Sécurité This revision does not change the security requirements of the Offer. Cette révision ne change pas les besoins en matière de sécurité de la présente offre.		

Instructions: See Herein

Instructions: Voir aux présentes

Acknowledgement copy required Accusé de réception requis	Yes - Oui <input type="checkbox"/>	No - Non <input type="checkbox"/>
The Offeror hereby acknowledges this revision to its Offer. Le proposant constate, par la présente, cette révision à son offre.		
Signature	Date	
Name and title of person authorized to sign on behalf of offeror. (type or print) Nom et titre de la personne autorisée à signer au nom du proposant. (taper ou écrire en caractères d'imprimerie)		
For the Minister - Pour le Ministre		

Solicitation No. - N° de l'invitation

W0114-11P047/A

Amd. No. - N° de la modif.

004

Buyer ID - Id de l'acheteur

kin519

Client Ref. No. - N° de réf. du client

W0114-11-P047

File No. - N° du dossier

KIN-1-36534

CCC No./N° CCC - FMS No/ N° VME

Bidders Questions and Canada's Responses

Question #9: Which certification is required for the company?

Clarification to Response #9: The bidder does not need to be CASA certified and CFAA certified. Their Technicians must be 427a---Sprinkler and fire protection installer or CFAA fire alarm technician or equal that satisfies the requirements of CAN/ULC-S536/S537

Question #13: We are members of CASA and our sub contractors for any fire alarm related work are CFAA. Is that acceptable?

Response #13: The bidder does not need to be CASA certified and CFAA certified. Their Technicians must be 427a---Sprinkler and fire protection installer or CFAA fire alarm technician or equal that satisfies the requirements of CAN/ULC-S536/S537

Question #14: The quarterly inspections are broken up into 3 different installments. However, only the first is described as Quarterly Wet; Are we to assume the other two are Quarterly Dry and Quarterly Pre-action?

Response #14: Yes, the quarterly inspections are broken up into 3 different installments: Quarterly Wet; Quarterly Dry and Quarterly Pre-action.

AMENDMENTS TO SOLICITATION

PART 5 - CERTIFICATIONS

2. Certifications Precedent to Issuance of a Standing Offer

2.5 Documents Required:

Delete:

2.5.5 A copy of Contractor's registration permit to show that they are a current member of the Canadian Automatic Sprinkler Association and a current member of the Canadian Fire Alarm Association.

Annex "F" Statement of Work

Delete:

1.4 Workmanship

.1 Contractor must be a current member of the Canadian Automatic Sprinkler Association (C.A.S.A.) and Canadian Fire Alarm Association (C.F.A.A.) and all journeymen and apprentices must be certified with C.A.S.A. And C.F.A.A..

Insert:

1.4 Workmanship

.1 Contractor's onsite technicians must be a 427a---Sprinkler and fire protection installer or CFAA fire alarm technician or equal that satisfies the requirements of CAN/ULC-S536/S537

2012

CFB KINGSTON

Orange quarterly inspection sprinklers, blue semi annual inspection for kitche system, pink semi annual