

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

| | |
|--|--|
| Title - Sujet Const.Svcs, Westmorland Inst, N.B. | |
| Solicitation No. - N° de l'invitation EC016-132714/A | Amendment No. - N° modif. 003 |
| Client Reference No. - N° de référence du client R.043939.001 | Date 2013-01-14 |
| GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3192 | |
| File No. - N° de dossier PWB-2-35125 (020) | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-02-06 | Time Zone Fuseau horaire Atlantic Standard Time AST |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB | Buyer Id - Id de l'acheteur pwb020 |
| Telephone No. - N° de téléphone (506) 636-5347 () | FAX No. - N° de FAX (506) 636-4376 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|--|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

Cette modification de l'invitation numéro trois (3) est soumise et comprend la modification numéro 3 suivante.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des documents de contrat.

Toutes autres conditions ne changent pas.

Addenda numéro 3.

1. **DESSINS**

1. **Drawing M202 (HEATING DETAILS & SCHEDULES)**

1. **Pump Schedule:** TDH Column units are listed in kPa in lieu of pa.
Replace reference to pa with Kpa

2. **Drawing M302 (VENTILATION CONTROLS & SCHEDULES)**

1. **Detail 8/M301:** Replace last note with: Dampers by Ventilation Contractor, Actuators by Controls Contractor.

2. **DEVIS**

1. **Specification Section 22 05 53: IDENTIFICATION**

1. **Section 22 05 53 2.3.6.1:** Pipe and Valve Identification Shall read Westmorland Institution Standards.

2. **Specification Section 22 07 19: THERMAL INSULATION FOR PIPING**

1. **Section 22 07 19 2.4:** Preformed Polystyrene WHW Vapour Barrier
Delete Section 2.4 in its entirety.

3. **Specification Section 22 21 23: PUMPS HYDRONIC SYSTEMS**

1. **Section 22 21 23 2.2:** Base mounted end suction type. Delete Section 2.2 in its entirety.

4. Specification Section 22 30 05: DOMESTIC WATER HEATERS

- 1. Section 22 30 05 2.1:** Section title shall read: Natural Gas Water Heater.

5. Specification Section 22 42 01: PLUMBING SPECIALTIES AND ACCESSORIES

- 1. Section 22 42 01 2.15:** Cold water buffer tank: delete 22 42 01 2.15 in its entirety.

6. Specification Section 22 51 00: BREECHING

- 1. Section 22 51 00 2.1:** Boiler Stack Metallic: Delete Section 2.1 in its entirety.

7. Specification Section 22 52 00: BOILERS

- 1. Section 22 52 00 2.4:** Shall read: Electronic combustion control relay with flame rod flame detector for combustion control and flame supervision.
- 2. Section 22 52 00 2.4.1:** Add Viessmann, NTI and Buderus.

8. Specification Section 22 52 10: HYDRONIC SPECIALTIES

- 1. Section 22 52 00 2.4.6:** Stainless steel screen with perforated size of 3mm.
- 2. Section 22 52 00 2.4.7:** - Working pressure: 860 kPa.
- 3. Section 22 52 10 2.8:** - Glycol Fill System: Delete Section 2.8 in its entirety. Refer to Section 22 42 01 2.9

9. Specification Section 23 07 13: THERMAL INSULATION FOR DUCTING

- 1. Section 23 07 13 2.5.1:** Replace CANVAS with Composite Material.

10. Specification Section 25 01 01: DIRECT DIGITAL CONTROLS SYSTEM

1. **Section 25 01 01 1.2:** System description: delete Section 25 01 01 -1.2 in its entirety.
2. **Section 25 01 01 1.4.3, .4 & .5:** Delete Sections 25 01 01 1.4.3, 25 01 01 1.4.4 and Section 25 01 01 1.4.5 in their entirety.
3. **Section 25 01 01 1.5:** Reference Standards: Delete Section 25 01 01 -1.5 in its entirety.
4. **Section 25 01 01 2.1:** Operators work station: replace entire section with .1 Tie into existing operators work station in building H-45
5. **Section 25 01 01 2.2:** Web Interface: replace entire Section with .1 To match institutions existing control system.
6. **Section 25 01 01 2.3:** Building Controller: Replace entire Section with .1 To match institutions existing control system.
7. **Section 25 01 01 2.4:** Central plant air handler application controllers: Replace entire Section with .1 To match institutions existing control system.
8. **Section 25 01 01 2.5:** Thermal unit application controller (AC unit): replace entire Section with .1 To match institutions existing control system.
9. **Section 25 01 01 2.6:** Electronic actuator and valves: delete Sections 25 01 01 2.6.6.2, 25 01 01 2.6.6.3, 25 01 01 2.6.6.4, 25 01 01 2.6.6.5, 25 01 01 2.6.6.6, 25 01 01 2.6.6.7, 25 01 01 2.6.8 Butterfly Valves and 25 01 01 2.6.9 Butterfly Valve Industrial Actuators.