

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 421
Saint John
New Brunswick
E2L 2B9

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 421
Saint John
New Bruns
E2L 2B9

Title - Sujet 50 Bed Living Unit, Westmorland Ins	
Solicitation No. - N° de l'invitation EC016-130878/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client R.043929.001	Date 2012-08-21
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3101	
File No. - N° de dossier PWB-2-35024 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2012-09-13	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Tender Amendment Number 3 is raised to include the following **Addendum No. 3.**

The following Addendum to the tender documents is effective immediately. This Addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 3

Specification

.1 Reference Specification Section 01 50 00 Temporary Facilities:

- 1 Amend Section 1.4.2, Contractors Site Office to read:
".2 Provide office / cabin of sufficient size to accommodate 3-4 people, equipped with one desk and 4 chairs. Provide heat and light to enable the Institutions Commissionaires to monitor movement of site personnel and equipment onto and off the site. Office can be either separate from or co-located with the General Contractors site office. Location to be agreed with Departmental Representative

.2 Reference Specification Section 04 21 13 Brick Masonry:

- 1 Amend Section 2.1.3, Acceptable Materials to read:
*".3 Acceptable Materials:
 .1 Shaw Brick, Model: Tapestry Blend for field brick & soldier course. (Colour and texture of sample to be confirmed by Departmental Representative)*

.3 Reference Specification Section 07 46 13 Preformed Metal Cladding / Siding Panels:

- 1 Amend Section 2.1.1.3, Thickness (Metal Cladding and Components) to read:
".3 Thickness: .76mm base metal thickness minimum.'
- 2 Amend Section 2.2.3, Thickness (Metal Fascia and Soffit) to read:
".3 Thickness: .76mm base metal thickness minimum.'

.4 Reference Specification Section 07 61 00, Sheet Metal Roofing System:

- 1 Amend Section 2.2.1.1, Thickness to read:
".1 Thickness: 0.76mm. "
- 2 Amend Section 2.2.1.3, Panel Width to read:
".3 Panel Width: 400mm"

.5 Reference Specification Section 07 61 00, Sheet Metal Roofing System:

- .1 Delete Section 2.4, Ice Shield & Roof Underlayment entirely and replace text as follows:

"2.4 Ice Shield & Roofing underlayment

- .1 SBS modified bitumen self-adhesive membrane, intended to be used as a roofing underlayment, suitable for service temperatures of -45 to 115C.*
 - .1 Thickness - 1.0 mm (40 mil)*
 - .2 Dimension - 22.9 x 0.91 m (75 ft x 36 in)*
 - .3 Roll weight - 20 kg (44 lb)*
 - .4 Top face - ..Split-back.. Tri-Laminate Woven Polyethylene*
 - .5 Underface - Silicone release ! lm*
 - .6 Breaking Strength, MD/XD ASTM D1970 11.3 / 15.4 kN/m (64 / 88 lb/in)*

- .7 Elongation at Break, MD/XD ASTM D1970 52 / 24 %
- .8 Tear Resistance ASTM D1970 375 / 400 N (84 / 90 lb)
- .9 Static Puncture ASTM D5602 400 N (90 lbf)
- .10 Adhesion to Plywood, 4.5 C ASTM D1970 175 N/m (12 lbf/ft)
- .11 Adhesion to Plywood, 24 C ASTM D1970 575 N/m (39.4 lbf/ft)
- .12 Low Temperature Flexibility ASTM D1970 Pass at -30 C (-22 F)
- .13 Water Vapour Permeance ASTM E96 1.25 ng / Pa.s.m2 (0.022 perm)
- .14 Nail Sealability ASTM D1970 Pass
- .2 Acceptable Materials:
 - .1 Soprema Inc., Model :Lastobond Shield HT
 - .2 Henry Company, Model: Blueskin PE200HT
 - .3 W. R. Grace & Company, Model Grace Ice & Water Shield HT

.6 Reference Specification Section 07 61 00, Sheet Metal Roofing System:

- .1 Amend Section 2.8.1.8, Acceptable Materials to read:
 - .8 Acceptable Materials:
 - .1 Roofers World Inc., Model Snostop LGB-4T, penetrating fixing type.
 - .2 Alpine Snow Guards, Model #117 Pipe-Style Snow Guard for Metal Roof"

.7 Reference Specification Section 07 62 00, Metal Flashing and Trim:

- .1 Amend Section 2.1.1.3, Thickness to read:
 - .3 Thickness: 0.76mm"


.8 Reference Specification Section 08 61 10 Solid Vinyl Frame Windows:


- .1 Amend Section 2.1.3, Description of Unit to read:
 - .3 Frame: extruded PVC, nominal perimeter frame depth of 73mm. Frame components to be steel reinforced. White Colour."

Drawings

.9 Reference Drawing A-306:

- .1 Detail 1/306 revised to show sheet metal backing for Snow Rail support in accordance with attached sketch ASK-01.



 Public Works and Government Services Canada	Tender	C.MILLIGAN PWGSC Project Manager	Travaux publics et Services gouvernementaux Canada	Soumission	50 BED LIVING UNIT WESTMORLAND INSTITUTE DORCHESTER, NB	project	project number R.043929.001	no. du projet ASK-001	drawing no. no. du dessin	Drawing title		designed date	
										REVISED SECTION DETAIL 1/306		WHW, CSC 2012/08/15	
Administrateur de projets TPSCG										approved date			
										approved date		D.BRENNAN 2012/08/15	
										R.TURNER 2012/08/15			