

Solicitation No. - N° de l'invitation

E0224-131985/A

Client Ref. No. - N° de réf. du client

R.040595.003

Amd. No. - N° de la modif.

001

File No. - N° du dossier

PWD-2-35101

Buyer ID - Id de l'acheteur

pwd008

CCC No./N° CCC - FMS No./N° VME

\*\*\*\*\*  
THE FOLLOWING AMENDMENT TO THE BID DOCUMENTS IS EFFECTIVE  
IMMEDIATELY. THE ADDENDUM SHALL FORM PART OF THE CONTRACT  
DOCUMENTS.  
\*\*\*\*\*

The following shall be added to and form part of the Plans and Specifications for this project.

Delete reference to Section 03 93 05 - Externally Bonded Fiber Reinforced Poymner(FRP) Strengthening System and replace with Section 03 93 00-Externally Bonded Fiber Reinforced Poymner(FRP) Strengthening System.

Section 03 93 00 - Externally Bonded Fiber Reinforced Poymner(FRP) Strengthening System-  
Item 1.4- Material Qualifications- "BASF MBrace composite strengthening system is an acceptable alternative to the Fyfe Tyfo Fibrwrap System outlined in the specifications. Number of layers of FRP and design based on loads shown in original contract documents using alternate are required to be determined by Engineer qualified to practice in Newfoundland and Labrador. If used, full design and calculations stamped by Engineer to be provided for alternate a maximum of 2 weeks after contract award."

**All other terms & conditions remain unchanged.**