

PART 1 - GENERAL

- | | | |
|-------------------------|----|---|
| <u>1.1 RELATED WORK</u> | .1 | Section 26 05 00 - Common Work Results - for Electrical. |
| | .2 | Section 26 98 00 - Testing, Adjusting and Balancing of Electrical Equipment and Systems. |
| <u>1.2 COORDINATION</u> | .1 | Coordinates starting of electrical equipment and systems with testing, adjusting and balancing, and demonstration and instruction of: <ul style="list-style-type: none"> .1 Electrical equipment and systems specified in Division 26. .2 Mechanical equipment and systems specified in Division 21, 22, 23 & 25. .3 Other equipment and systems specified in other Divisions. |
| | .2 | Where any equipment or system requires testing, adjusting or balancing prior to starting, ensure that such work has been completed prior to starting of electrical equipment and systems. |

PART 2 - PRODUCTS

- | | | |
|---------------------|----|-----------|
| <u>2.1 NOT USED</u> | .1 | Not Used. |
|---------------------|----|-----------|

PART 3 - EXECUTION

- | | | |
|---------------------------------|----|--|
| <u>3.1 STARTING MOTORS</u> | .1 | Prior to starting motors: <ul style="list-style-type: none"> .1 Verify phase rotation at motor control centres. .2 Confirm motor nameplate data with motor starter heater overloads. |
| <u>3.2 ENERGIZING EQUIPMENT</u> | .1 | Complete all testing and provide testing result to Departmental Representative prior to energizing equipment. |
| | .2 | Confirm equipment nameplate data with characteristics of power supply. |