

Solicitation No. - N° de l'invitation

E0224-131985/A

Amd. No. - N° de la modif.

004

Buyer ID - Id de l'acheteur

pwd008

Client Ref. No. - N° de réf. du client

R.040595.003

File No. - N° du dossier

PWD-2-35101

CCC No./N° CCC - FMS No./N° VME

THE FOLLOWING AMENDMENT TO THE BID DOCUMENTS IS EFFECTIVE
IMMEDIATELY. THE ADDENDUM SHALL FORM PART OF THE CONTRACT
DOCUMENTS.

The following shall be added to and form part of the Plans and Specifications for this project.

Reference Drawing S1.0: Beam Reinforcing Level 2 - Add general note: FRP system applied to underside of slab to be 2 hour fire resistance rated complete with ULC Design number.

All other terms & conditions remain unchanged.